

INSTITUTE OF GENOMICS & INTEGRATIVE BIOLOGY

(Council of Scientific & Industrial Research)

Near Jubilee Hall, Delhi University Campus,

Mall Road, Delhi- 110007.

Tender Document

Name of Work: Operation & Comprehensive Maintenance of Fire Alarm and Fire Fighting System at I.G.I.B., Mall Road and Mathura Road, Delhi.

Tender No. 05 / 2016 – Works (Electrical)

Sale of Tender: _____ up to 10/06/2016.

Submission of Tender: _____ 13/06/2016 up to 3:00 P.M.

Date of time of Opening of Tender : _____ 13/06/2016 at 3:30 P.M.

Signature of Tenderer with the seal of the firm

INSTITUTE OF GENOMICS & INTEGRATIVE BIOLOGY

(Council of Scientific & Industrial Research)

Near Jubilee Hall, Delhi University Campus,

Mall Road, Delhi- 110007.

Name of Work: Operation & Comprehensive Maintenance of Fire Alarm and Fire Fighting System at I.G.I.B., Mall Road and Mathura Road Delhi.

CONTENTS

S.No.	Description	Page No.
1.	Contents	2
2.	Notice Inviting Tenders	3-5
3.	Scope of Work for Part-A(Mall Road)	6
4.	Man Power & Terms of Payment	7
5.	Annexure-AI	8
6.	Annexure-AII	9
7.	Contract Obligations	10-11
8.	Scope of Work for Part –B(Mathura Road)	12
9.	Man Power & Terms of Payment	13
10.	Annexure-BI	14
11.	Annexure-BII	15
12.	Contract Obligations	16-17
13.	Financial Bid	18-24
14.	Abstract of Cost	25
15.	Annexure-III (Break-up Price per Month)	26
16.	General Conditions	27-41
17.	Special Conditions	42-45

Note:

1. Tenderer should confirm that they have received all the above papers. The nature and the place of the work can be seen in the IGIB, Mall Road, Delhi-110007.

DD/Pay order NO. _____ Drawn on Bank and branch _____
DATED _____

TENDER ISSUED TO:

M/s _____
_____ TELEPHONE NO. (IF ANY): _____

Tender cost deposited vide DD No. _____ dated _____ or .
So, tender No. _____ issued.

SIGNATURE OF THE TENDERER

SIGNATURE OF THE OFFICER
ISSUING TENDER

Signature of Tenderer with the seal of the firm

INSTITUTE OF GENOMICS & INTEGRATIVE BIOLOGY

(Council of Scientific & Industrial Research)

Near Jubilee Hall, Delhi University Campus

Mall Road, Delhi-110007.

NOTICE INVITING TENDERS

Tenders are hereby invited for the work of Operation & Comprehensive Maintenance of Fire Alarm and Fire Fighting System at I.G.I.B. Mall Road & Mathura Road, Delhi (For Campus) from contractors of appropriate class of CPWD, Railways, MES, Post & Telegraph Department State PWD'S, Semi-Govt. Organisations and/or from those who have carried out minimum of One/two/three similar works for CSIR or its National Laboratories, Govt. Departments, Semi-Govt organisations amounting to Rs.27.46Lacs/Rs. 20.60 Lacs/ Rs. 13.73 lacs respectively in last five years. The tenderers are required to produce proof of fulfilling these conditions along with latest Income Tax Clearance, PF/ESI, Tin No Certificate while making request for issue of Tender documents.

1. The NIT document containing Scope of work, General conditions of contract, Special condition of contract, Schedule of quantity, etc are being enclosed for reference.
2. Estimated cost of the work is **Rs. 34.32 Lacs (Rupees Thirty Four Lac Thirty Two Thousand only)**.
3. Time for carrying out the work will be **One year** and the date of commencement shall be reckoned from the date of issue of award letter. However, the same can be extended for a period of further one year on satisfactory performance of the contract based on mutually agreed terms and conditions.
4. Complete Contract documents to be compiled by the tenderer whose tender may be accepted, can be seen at the office of Controller of Administration, INSTITUTE OF GENOMICS & INTERGRATIVE BIOLOGY Mall Road, Delhi-110007.
5. Tenders should be on the specified form (Non-transferable) which may be obtained from the of **SO(W&S) I.G.I.B. Mall Road, Delhi-110007** during office hours on payment of Rs.1,000/- in the form of DD/Pay order drawn in favour Director IGIB. Sale of tenders shall be stopped two days before the date of opening of tenders. The same can be seen from our website www.igib.res.in but downloaded tender will not be accepted.
6. Tenders should be submitted in double sealed covers superscribed with the name of the work, date and time of opening written both on the inner and outer envelopes. They will be received upto 3.00 P.M on 13/6/2016 and will be opened at 3.30 P.M on the same day in the office of **SO(W) I.G.I.B. Mall Road, Delhi-110007**. Tender should be dropped in the tender box before the closing date and time indicated. In case these are sent by post these should be sent by Regd. Post/speed post addressed to **Director, I.G.I.B. Mall Road, Delhi-110007**. Tenderers are to ensure that they post the tender well in advance so as to reach before the closing time and date indicated.
7. The Earnest Money amounting to **Rs.68,700/- (Rupees. Sixty Eight Thousand Seven Hundred Only)** in the form of demand draft or pay order of a scheduled bank and drawn in favour of **Director, I.G.I.B, Delhi-110007** should accompany the tender. Tenders received without earnest money will be rejected.
8. The Employer does not bind himself to accept the lowest or any tender and reserves the right of accepting the whole or any part of the tender and the tenderers shall be bound to perform the same at the rates quoted.
9. Canvassing in connection with the tenders is prohibited and the tenders submitted by the contractor who resort to canvassing are liable for rejection.
10. The tenderer shall not be permitted to tender for works in the concerned unit of CSIR in which a relative is posted in the grade between Controller of administration and Junior Engineer, (both inclusive). He shall also intimate the names of persons who are working with him in my capacity or subsequently employed by him and who are relatives as mentioned above.

Signature of Tenderer with the seal of the firm

NOTE: A person shall be deemed to be a relative of another if, (a) they are members of a Hindu undivided family; or (b) they are husband and wife; or (c) the one is related to the other in the following manner: Father, Mother (including step mother), Son (including step son), Son's wife, Daughter (including stepdaughter), Father's father, Son's son, Son's son's wife, Son's daughter, Son's daughter's husband, Daughter's husband, Daughter's son, Daughter's son's wife, Daughter's daughter, Daughter's daughter's husband, Brother (including step brother), Brother's wife, Sister (including step sister), Sister's husband.

- 11 Tender submitted shall remain valid for 90 days from the date of opening for purpose of acceptance and award of work, validity beyond 90 days from the date of opening shall be mutual consent.
- 12 The tenderer shall quote rates both in figures and words. He shall also workout the amount for each item of work and write in both figures and words. On check if there are differences between the rates quoted by the tenderer in words and figures or in the amount worked out by him, the following procedure shall be followed:
 - (i) When there is a difference between the rates in figures and in words, the which correspond to the amounts worked out by the tenderer shall be taken as correct.
 - (ii) When the amount of an item is not worked out by the tenderer or it does not correspond with the rate written either in figures or in words, the rate quote by the tenderer in words shall be taken as correct.
 - (iii) When the rate quote by the tenderer in figures and in words tallies but the amount is not worked out correctly, the rate quoted by tenderer shall be taken as correct and not the amount.
- 13 The tenderer should see drawing and in case of doubt, obtain required particulars, which may in any way influence his tender from the Engineer as no claim whatsoever will be entertained for any alleged ignorance thereof.
- 14 Before tendering, the tenderer shall inspect the site to fully acquaint himself about the condition in regard to accessibility of site, nature and extent of ground working condition of site and location including movement of labour etc. required for satisfactory execution of the work contract. No claim whatsoever on such account shall be entertained by the Employer in any circumstances.
- 15 Earnest money will be forfeited if the contractor fails to commence the work as per letter of award. If any tenderer with drawn this tender within the validity period of makes any modification in terms and condition of the tender which are not acceptable to the Department, then IGIB shall without prejudice to any right or remedy, be a livery to forfeit 50% (Fifty Percent) of the Earnest Money absolutely.
- 16 Except writing rates and amount, the tenderer should not write any condition or make any changes, additions, alterations and modifications in the printed form of tenders. Tenderers who are desirous to offer rebate the same should be brought out separately in the covering letter and submitted alongwith the tender.
- 17 Some of the provisions of General Conditions of Contract are given below. Interpretation however shall be as given in the General Conditions of Contract.
 - (a) DEFECTS LIABILITY PERIOD: One months from the date of completion as certified by the Employer.
 - (b) MINIMUM VALUE OF WORK FOR THE INTERMEDIATE CERTIFICATE: Rs. 1,50,000/- (Rupees One Lac Five Thousand only). Intermediate certificate for a lesser amount can be admitted for payment at the discretion of the Engineer.
 - (c) SECURITY DEPOSIT: Security deposit shall be deducted from the running bills at 10% of the gross value of work done till the sum along with deposited EMD will amount equal to 5% of the tendered value of the work. In addition, contractor shall be required to deposit an amount equal to 5% of the tendered value to the contract as performance guarantee within the period prescribed for commencement of work in the letter of award issued to him.
 - (d) COMPENSATION: Contractor shall pay as compensation an amount equal to one per cent or such smaller amount as the Employer (whose decision in writing shall be final) may decide on the cost of the whole

Signature of Tenderer with the seal of the firm

work as show in the agreement, for every week that the work remains uncommenced or unfinished or due quantity of work remains incomplete after the work proper dates. Compensation to be paid shall not exceed ten per cent of the estimated cost of the work as showing in the agreement.

- (e) Escalation clause is not applicable in this case.
 - (f) No material will be supplied by the department. Selection of material to be used in the work will rest with the employer.
18. Materials to be issued: No material will be issued by the department. Contractor has to arrange all materials including cement & steel required for this work.
 19. Clause 28 of the Condition of Contract for works i.e. "ESCLATION" will not be applicable in this contract.
 20. All renderers should submit the proof of their registration with Sales Tax Department while tendering for works in N.C.T. of Delhi as per Works Contract Act, 1999. Deduction of Sales Tax will be made from their running / final bill on all works as applicable within N.C.T. of Delhi.
 21. The contractor shall have to dispose of all the building rubbish (Malba) accumulated during execution, suitably outside the campus of I.G.I.B. Nothing extra shall be paid on this account.
 22. The work is to be carried out in running office, the contractor should plan the execution in such a way that working of office is not disturbed. Nothing extra shall be paid on this account.
 23. Any damages incurred during construction shall be rectified by the contractor without any extra cost.

Signature of Tenderer with the seal of the firm

Part –A (CSIR-IGIB, Mall Road)

Name of work:- **Comprehensive Maintenance & Operation of Fire Alarm and Fire Fighting System at I.G.I.B., Mall Road, Delhi-110007**

SCOPE OF WORK

IGIB building comprises of two blocks. First is the main block having basement plus six floors and other is the administrative block having Basement plus three floors. The multistoried building has been provided with Automatic Fire Alarm system and Fire Fighting through Wet Risers and Fire Extinguishers for fire fighting. There is one separate Fire Fighting pump room adjacent to U.G. water tank having electrically operated Fire Fighting main pump, Jockey pump, Diesel pump and electrical control panel for pumps / pump motors. Building basement is provided with sprinkler system and necessary pumping system is located pump room.

At present Fire Alarm and Fire Fighting are functional. It would thus be responsibility of the intending firm to inspect the complete installation and after assessing the situation and going through the Bill of Quantities they should quote their rates. Rates of additional works needed to be carried out to make the system fully functional, if any, must be mentioned separately in the tender with their detailed specifications, quantities and rates, as thereafter, no payment for any extra work for making the system fully functional, considered essential, shall be made.

PA System is newly installed and under warranty till Aug 2014 and will be covered under AMC wef 01/09/2014

The firm must have to collect the Clearance / No objection Certificate from the Delhi Fire Service, Department of NCT Delhi and also co-ordinate for all the Liaison work with them if required at any stage. The fees for getting the Clearance / No objection Certificate from the Delhi Fire Service will be reimbursed by the Department on production of bill/voucher/receipt.

Works that are not covered in the scope of work are enclosed as in Annexure –A- I

Moreover, during the period of comprehensive maintenance contract of two year, no payment towards replacement of parts, spares or consumables shall be entertained. The firm has to hand over the complete system fully functional to the department on completion of the work.

The firm has to rectify the minor defects within 24 hours and major defects within a week (making alternative arrangement) failing which penalty for non performance @ 1% of the total work per day will be imposed and in the event of any damage to the property or life arising out of non-performance, shall be contractor's sole responsibility.

During execution of Maintenance contract, the firm will co-ordinate with Engineer-in-charge on regular basis for effective servicing and operation of Fire Alarm and Fire Fighting System. The contractor shall to carry out the work as per particulars mentioned in Annexure A- II.

The brief description of the items have been mentioned in the schedule of quantity. Any omission in the description of the item will not absolve the contractor for its responsibility to complete the work in satisfactory manner.

The tenderer may visit the site / IGIB, Mall Road before submitting the tender so that they can see the existing system for any clarification.

As IGIB is very busy laboratory building, the work may be carried out beyond office hours and on holidays without any extra claim. Contractor must take prior permission from the concerned authority to carry out any work beyond normal office hours and on holidays.

Note

Signature of Tenderer with the seal of the firm

MAN POWER

The firm shall have to keep a minimum team of 02 (Two) persons round the clock in 03 shifts. The staff should have adequate qualification and experience. Out of the allocated persons 03 should be trained electricians/fitter / Fire & Safety. The Supervisor should be a graduate with certificate in Fire & safety & knowledge of fire fighting. Beside the firm will deploy senior engineer as and when required but at least once in a week to check up periodically maintenance.

Total minimum manpower required and hours of duty of them are as mentioned below :-

Sl. No.	Manpower	Qty	Duty Hours
1	Fire Operator/Electrician/Fitter	3 nos. (1 in each shift of 8 hours)	6:00 AM to 2:00 PM 2:00 PM to 10:00 PM 10:00 Pm to 6:00 AM
2	Electric/Diesel pump helper	3 nos. --- do ---	6:00 AM to 2:00 PM 2:00 PM to 10:00 PM 10:00 Pm to 6:00 AM
3	Supervisor	01	08 hrs. in a week

A penalty will be imposed for absence of contractor's Fire Operator & Helper during the contract period.

- a. Absence of Fire Operator @ Rs.500/- per day.
- b. Absence of Helper @ Rs.400/- per helper per day.

Further, in case of non-operation of any systems, penalty as below will be imposed:

In minor complaints – If the firm does not attend within 24 hrs of the lodging of complaint, a penalty of Rs.1000/- per day will be imposed till the defect is rectified.

In major complaints – If the firm does not attend within 48 hrs of the lodging of complaint, a penalty of Rs.2000/- per day will be imposed till the defect is rectified.

If the defective equipment is liable to take longer time for repairing, the firm will provide alternative equipment (free of charge) till the faulty equipment is repaired and re-fixed. It is to mention with that the penalty charges will start after 48 hrs if the faulty equipment is not replaced with standby equipment.

After expiry of the contract, the firm will have to hand over complete system along with all the accessories to the department in fully functional condition.

Power and water supply shall be made available to the contractor by the department free of charge.

TERMS OF PAYMENT

Quoted rate will remain fixed during the 2 years contract period and it should be inclusive of all taxes, minimum wages, ESI, PF, Service tax etc. Nothing shall be given extra apart from the quoted price.

Payment for the work will be made as under:-

Monthly payment will be made after successful completion of work under Sub Head I.

Yearly payment will be made after successful completion of work under Sub Head II.

Yearly payment will be made after successful completion of work under Sub Head III.

Signature of Tenderer with the seal of the firm

WORKS NOT COVERED IN SCOPE OF WORK

Replacement of following accessories / parts / equipment:

S.NO.	Description	Qty.	Unit
1	Following size Gate Valve complete in all respect		
	i) 150 mm	7	Nos.
	ii) 100 mm dia	3	Nos.
	iii) 80 mm dia	2	Nos.
	iv) 50 mm dia		
2	Following size C.I Non Return Valve complete in all respect		
	i) 150 mm	7	Nos.
	ii) 100 mm dia	2	Nos.
	iii) 80 mm dia	2	Nos.
	iv) 50 mm dia		
3	Pressure guage 0-21 Kg/cm complete in all respect	6	Nos.
4	Air release valve	2	Nos.
5	Battery		
	i) 180 AH, 12V Exide	4	Nos.
	ii) 60 AH, 12V Exide	2	Nos.
6	Smoke detector	250	Nos.
7	Heat detector	60	Nos.
8	Response indicator	66	Nos.
9	Amplifiers	2	Nos.
10	Batteries 7 AH	26	Nos.
11	Rewinding of 60 HP motor	2	Nos.
12	Rewinding of 15 HP motor Jockey pump set	1	Nos.
13	Repair and Maintenance of DG set		
	(i) 380 KVA	02	Nos.
	(ii) 160 KVA	01	No.

Signature of Tenderer with the seal of the firm

Special Conditions

MAINTENANCE SCHEDULE

Maintenance of Fire Alarm and Fire Fighting System

The following work / checks are required to be performed on Daily / Fortnight / Monthly / Quarterly / Half Yearly basis and record all the activities in the log book with date and time.

1. Daily Checks

- a) Check the power supply positions of all the panels placed in various floors and building.
- b) Daily check of the water pressure in the system minimum 3.5 kgs / sqm.
- c) Daily running of the fire hydrant pump, motor and diesel engine.
- d) Daily checks of leakage etc. in the system.
- e) Daily check of bell and siren for proper working.
- f) Monthly cleaning of system i.e. draining the same etc. as required.
- g) Testive of DA System, checking of all speakers at all floors.
- h) Check any fault if indicated on any of the panels, rectify the same immediately.
- i) Running of water pump, checking level of water in O/H water tank, drinking water tank, ground tank.
- j) Working of DG sets (500 KVA, 165 KVA, 380 KVA), Diesel Engines of Fire Pumps.

2. Fortnightly Checks

- a) Operational readiness of system during mains failure.
- b) Check battery water level and specific gravity.
- c) Functioning of Sprinkler System.

3. Monthly Checks

- a) Check the fire circuit of each zone from the panels.
- b) Check whether signals of fire and fault gets transmitted from zonal panel to main panel.
- c) Performance check of the hooters should be done. Performance check of manual call points.
- d) Electrical Control Panels (Tightness, Cleaning).

4. Quarterly Checks

- a) Check fault circuit of each zone by actually disconnecting wire or by removing a detector.
- b) Check fir circuits by actual smoke to one detector of each zone.
- c) Cleaning of all type of detectors with a cloth piece from outside.
- d) Conduct fire work drill in Institute (in presence of DELHI FIRE SERVICE OFFICER).

5. Half Yearly

- a) Clean all the detectors with cleaner.

NOTE:- above activity has to be divided on weekly basis for available number of smoke detectors so that all the detectors are checked for their performance and cleaned once in six months.

- b) Performance of system and smoke detectors before they are cleaned.
- c) Servicing of Jockey Pump, Fire Pump, Motors and DG (Two times in one year)

NOTE:- No Tool and plant shall be supplied by the department.

Signature of Tenderer with the seal of the firm

Name of work:- Operation and Comprehensive Annual Maintenance of Fire Alarm and Fire Fighting system installed at Mall Road, Delhi.

Contractor's Obligations

1. Cleaning material such as vim, surf, cotton, old dhotis, pilot lamp for indicating lamp, pvc tape, gland dori, grease for pump and motors shall be supplied by the contractor at site.
2. All spare parts and consumable required Fire Alarm & Fire fighting system will be replaced free of cost.
3. All spare parts and consumables required for keeping the wet riser system in operational condition necessary repairs / overhauling of engine / pump / motor & replacement of parts shall be carried out by the firm free of cost as a part of this contract.
4. If the visits are not made as per terms, by recovery shall be made by the department on double of prevailing market rates for which the decision of the department, shall be final and binding on the contractor and he should not have any claim in this regard.
5. The operation of DG sets 2 x 380 KVA, 500 KVA (AMF Panel), 165 KVA DG set (AMF Panel) 4 x 7.5 HP & 2 x 1.5 HP water lifting pump set of this Institute have to carried out by the same men-power as and when required without any extra cost implication.
6. The firm has to engage trained technical staff and helper for routine maintenance.
7. The firm as under will maintain the logbook for each system under maintenance.
 - After each maintenance / testing, the test details shall be entered in the logbook with dates and result achieved.
 - After carrying out each test, the entry in the logbook same shall be counter signed by Maintenance Engineer.
 - Without prior approval, no fittings / materials shall be removed for repairs. It shall be contractor's responsibility to provide alternative arrangement of such items during repair period. After repaired up, put back in to its original position so that the system remains fully functional all the time.
8. The checking and maintenance of the batteries of the system shall be carried out as regular interval to maintain specific gravity, distilled water level, battery terminals check & replace.
9. The servicing of the system shall be carried out periodically including fire detection system and random checking of smoke and heat detectors periodically by heat and smoke.
10. The system shall be kept fully in working condition till the completion of contract. The firm must have to arrange handing over of the total system in fully functional condition on completion of the contract.
11. The demonstration of the working of the system shall be given as and when desired by the Engineer-in-charge.
12. All the materials required for replacement shall be of ISI approved.
13. The check list and test requirements mentioned are of general nature and in case specific checks / tests under the guidelines of Delhi Fire Office or some repairs / modifications are considered necessary for efficient working of equipment and keeping the system fully functional whether included or not in either specification or in bill of quantities have to be brought out at tender stage itself and thereafter no claim shall be entertained whatsoever the reason may be for any extra work considered essential for maintaining the system fully functional.

Signature of Tenderer with the seal of the firm

14. In case of fire, the crews available on duty will initiate fire fighting actions immediately and simultaneously inform the Delhi Fire Office and occupants / staff for vacating the area under fire.
15. The firm shall depute one Supervisor / qualified Engineer to check the whole system every week for one day and shall maintain a proper record duly signed by them and got countersigned by their visits from the Engineer of the Employer. The firm shall submit a list of persons deployed for the work.
16. The firm has to arrange for testing both the fire pumps in the presence of Engineer once in a fortnight. The test include running of the pressurization pumping set in case of loss of pressure of fire hydrant system and running of diesel engine pump by artificial closure of electricity. Creating the pressure loss in the pipelines shall test the electricity driven pump set. Test pressure at the farthest end, bottom most ends and at pump delivery. One of the yard hydrants shall also be taped for operation on the same day by creating the desired jet, such test shall be done at least once in a month in the presence of Engineer.
17. The firm has to demonstrate to the department proper working of complete automatic fire detector and fire fighting system by testing the system daily for a period of 45 minutes and also carry out mock drill once in a six month or as & when required by the department. The firm shall be responsible for working conditions of the system all the time and all the parts found defective / damaged have to be replaced free of cost by the firm and in the event of failure of system at the hour of need, firm shall be held responsible and has to meet all the losses.
18. The firm shall be responsible for maintaining all accessories, equipment, panels, installed and being operated by them loss or damage of any component, line valves etc. due to faulty operation shall be contractor's responsibility and the contractor shall have to replace the same, make good the damages. In case of hydrant pipes, if the damages are caused due to 3rd party or due to ageing, the decision of the Engineer shall be final with regard to the admissibility of payments towards extra cost of repairs / replacement to the annual maintenance contract.
19. The Engineer or his representative shall have access to installation during all hours.
20. Maintaining liaison with fire security department in case of fire, test being conducted to check the operation / readiness of the system shall be contractor's responsibility.
21. Providing all spares and consumable items of the system shall be contractor's responsibility only.
22. Non-availability of competent staff / engineers. Unjustified delay in modification of faults noticed and unsatisfactory maintenance of the complete system shall be treated as a break of contract. Department may consider imposing of suitable penalty or deduction of suitable amount from the payment to be made to the firm in such case. The decision of the department shall be final and binding in this regard.
23. The servicing of the firm pumps, jockey pump, motor and engine shall be done twice in a year. During the 1st quarter and 3rd quarter of the contract period to the entire satisfaction of the Engineer nothing extra shall be paid on this account. The department will not provide H. S. diesel for trail/testing. The water and electricity will be provided by the department free of cost for its running and maintenance.
24. Painting of MS pipes and fittings with synthetic enamel paint if Asian/Berger make related to fire fighting system will be done once in a year.
25. I/We agree to pay minimum wages as per the Labor Department Government of Delhi. + PF + ESIC etc. Payment will be made on 7th day of every month.
26. Two sets of Uniforms + Identity Card + 1 Pair of Safety Shoes will be given to all the workers within 15 days of award of work and it will be replaced as and when required.

Signature of Tenderer with the seal of the firm

Part-B(CSIR-IGIB, Mathura Road)

Name of work:- Comprehensive Maintenance & Operation of Fire Fighting System at I.G.I.B., South Campus, Delhi-110025

SCOPE OF WORK

IGIB, south campus comprises of two building. First is the DG-1 building i.e main block having basement plus four floors and other is the ISSH building having Basement plus eight floors. The multistoried building has been provided with Sprinkler, Fire Fighting through Wet Risers and Fire Extinguishers for fire fighting. There is two separate Fire Fighting pump room for DG-1 building & ISSH building adjacent to U.G. water tank having electrically operated Fire Fighting main pump, Jockey pump, Diesel pump and electrical control panel for pumps / pump motors. Building basement is provided with sprinkler system and necessary pumping system is located pump room.

At present Fire Fighting are functional. It would thus be responsibility of the intending firm to inspect the complete installation and after assessing the situation and going through the Bill of Quantities they should quote their rates. Rates of additional works needed to be carried out to make the system fully functional, if any, must be mentioned separately in the tender with their detailed specifications, quantities and rates, as thereafter, no payment for any extra work for making the system fully functional, considered essential, shall be made.

The firm must have to collect the Clearance / No objection Certificate from the Delhi Fire Service, Department of NCT Delhi and also co-ordinate for all the Liaison work with them if required at any stage. The fees for getting the Clearance / No objection Certificate from the Delhi Fire Service will be reimbursed by the Department on production of bill/voucher/receipt.

Works that are not covered in the scope of work are enclosed as in **Annexure – B-I**

Moreover, during the period of comprehensive maintenance contract of two year, no payment towards replacement of parts, spares or consumables shall be entertained. The firm has to hand over the complete system fully functional to the department on completion of the work.

The firm has to rectify the minor defects within 24 hours and major defects within a week (making alternative arrangement) failing which penalty for non performance @ 1% of the total work per day will be imposed and in the event of any damage to the property or life arising out of non-performance, shall be contractor's sole responsibility.

During execution of Maintenance contract, the firm will co-ordinate with Engineer-in-charge on regular basis for effective servicing and operation of Fire Fighting System. The contractor shall to carry out the work as per particulars mentioned in **Annexure B-II**.

The brief description of the items have been mentioned in the schedule of quantity. Any omission in the description of the item will not absolve the contractor for its responsibility to complete the work in satisfactory manner.

The tenderer may visit the site / IGIB, South Campus before submitting the tender so that they can see the existing system for any clarification.

As IGIB South campus is very busy laboratory building, the work may be carried out beyond office hours and on holidays without any extra claim. Contractor must take prior permission from the concerned authority to carry out any work beyond normal office hours and on holidays.

Note

Signature of Tenderer with the seal of the firm

MAN POWER

The firm shall have to keep a minimum team of 02 (Two) persons round the clock in 03 shifts. The staff should have adequate qualification and experience. Out of the allocated persons 03 should be trained electricians/fitter / Fire & Safety. The Supervisor should be a graduate with certificate in Fire & safety & knowledge of fire fighting. Beside the firm will deploy senior engineer as and when required but at least once in a week to check up periodically maintenance.

Total minimum manpower required and hours of duty of them are as mentioned below :-

Sl. No.	Manpower	Qty	Duty Hours
1	Fire Operator/Electrician/Fitter	3 nos. (1 in each shift of 8 hours)	6:00 AM to 2:00 PM 2:00 PM to 10:00 PM 10:00 Pm to 6:00 AM
2	Electric/Diesel pump helper	3 nos. --- do ---	6:00 AM to 2:00 PM 2:00 PM to 10:00 PM 10:00 Pm to 6:00 AM
3	Supervisor	01	08 hrs. in a week

A penalty will be imposed for absence of contractor's Fire Operator & Helper during the contract period.

- c. Absence of Fire Operator @ Rs.600/- per day.
- d. Absence of Helper @ Rs.400/- per helper per day.

Further, in case of non-operation of any systems, penalty as below will be imposed:

In minor complaints – If the firm does not attend within 24 hrs of the lodging of complaint, a penalty of Rs.1000/- per day will be imposed till the defect is rectified.

In major complaints – If the firm does not attend within 48 hrs of the lodging of complaint, a penalty of Rs.2000/- per day will be imposed till the defect is rectified.

If the defective equipment is liable to take longer time for repairing, the firm will provide alternative equipment (free of charge) till the faulty equipment is repaired and re-fixed. It is to mention with that the penalty charges will start after 48 hrs if the faulty equipment is not replaced with stand by equipment.

After expiry of the contract, the firm will have to hand over complete system along with all the accessories to the department in fully functional condition.

Power and water supply shall be made available to the contractor by the department free of charge.

TERMS OF PAYMENT

Quoted rate will remain fixed during the 2 years contract period and it should be inclusive of all taxes, minimum wages, ESI, PF, Service tax etc. Nothing shall be given extra apart from the quoted price.

Payment for the work will be made as under:-

Monthly payment will be made after successful completion of work under Sub Head BI.

Yearly payment will be made after successful completion of work under Sub Head BII.

Yearly payment will be made after successful completion of work under Sub Head BIII.

Signature of Tenderer with the seal of the firm

WORKS NOT COVERED IN SCOPE OF WORK

Replacement of following accessories / parts / equipment:

S.NO.	Description	Qty.	Unit
1	Following size Gate Valve complete in all respect		
	v) 150 mm	10	Nos.
	vi) 100 mm dia	9	Nos.
	vii) 80 mm dia	10	Nos.
	viii) 65 mm dia	10	
2	Following size C.I Non Return Valve complete in all respect		
	v) 150 mm	7	Nos.
	vi) 100 mm dia	2	Nos.
	vii) 80 mm dia	2	Nos.
	viii) 50 mm dia		
3	Pressure guage 0-21 Kg/cm complete in all respect	8	Nos.
4	Air release valve	2	Nos.
5	Battery		
	iii) 180 AH, 12V Exide	2	Nos.
6	AFC detector	-	Nos.
7	BFC detector	-	Nos.
11	Rewinding of 60 HP motor	2	Nos.
12	Rewinding of 15 HP motor Jockey pump set	2	Nos.
13	Repair and Maintenance of fire DG set	02	Nos.

Special Conditions

MAINTENANCE SHEDULE

Maintenance of Fire Fighting System:

The following work / checks are required to be performed on Daily / Fortnight / Monthly / Quarterly / Half Yearly basis and record all the activities in the log book with date and time.

1. Daily Checks

- k) Check the power supply positions of all the panels placed in various floors and building.**
- l) Daily check of the water pressure in the system minimum 3.5 kgs / sqm.**
- m) Daily running of the fire hydrant pump, motor and diesel engine.**
- n) Daily checks of leakage etc. in the system.**
- o) Monthly cleaning of system i.e. draining the same etc. as required.**
- p) Check any fault if indicated on any of the fire panels, rectify the same immediately.**
- q) Running of water pump, checking level of water in O/H water tank, drinking water tank, ground tank.**
- r) Working of Diesel Engines of Fire Pumps.**

2. Fortnightly Checks

- d) Operational readiness of system during mains failure.**
- e) Check battery water level and specific gravity.**
- f) Functioning of Sprinkler System.**

3. Monthly Checks

- e) Check the fire circuit of each zone from the panels.**
- f) Electrical Control Panels (Tightness, Cleaning).**

4. Quarterly Checks

- e) Conduct fire work drill in Institute (in presence of DELHI FIRE SERVICE OFFICER).**

5. Half Yearly

- d) Servicing of Jockey Pump, Fire Pump, Motors and DG (Two times in one year)**

NOTE:- No Tool and plant shall be supplied by the department.

Signature of Tenderer with the seal of the firm

Name of work:- Operation and Comprehensive Annual Maintenance of Fire Fighting system installed at IGIB South campus, Delhi-110025.

Contractor's Obligations

1. Cleaning material such as vim, surf, cotton, old dhotis, pilot lamp for indicating lamp, pvc tape, gland dori, grease for pump and motors shall be supplied by the contractor at site.
2. All spare parts and consumable required Fire fighting system will be replaced free of cost.
3. All spare parts and consumables required for keeping the wet riser system in operational condition necessary repairs / overhauling of engine / pump / motor & replacement of parts shall be carried out by the firm free of cost as a part of this contract.
4. If the visits are not made as per terms, by recovery shall be made by the department on double of prevailing market rates for which the decision of the department, shall be final and binding on the contractor and he should not have any claim in this regard.
5. The firm has to engage trained technical staff and helper for routine maintenance.
6. The firm as under will maintain the logbook for each system under maintenance.
 - After each maintenance / testing, the test details shall be entered in the logbook with dates and result achieved.
 - After carrying out each test, the entry in the logbook same shall be counter signed by Engineer In-charge.
 - Without prior approval, no fittings / materials shall be removed for repairs. It shall be contractor's responsibility to provide alternative arrangement of such items during repair period. After repaired up, put back in to its original position so that the system remains fully functional all the time.
7. The checking and maintenance of the batteries of the system shall be carried out as regular interval to maintain specific gravity, distilled water level, battery terminals check & replace.
8. The system shall be kept fully in working condition till the completion of contract. The firm must have to arrange handing over of the total system in fully functional condition on completion of the contract.
9. The demonstration of the working of the system shall be given as and when desired by the Engineer-in-charge.
10. All the materials required for replacement shall be of ISI approved.
11. The check list and test requirements mentioned are of general nature and in case specific checks / tests under the guidelines of Delhi Fire Office or some repairs / modifications are considered necessary for efficient working of equipment and keeping the system fully functional whether included or not in either specification or in bill of quantities have to be brought out at tender stage itself and thereafter no claim shall be entertained whatsoever the reason may be for any extra work considered essential for maintaining the system fully functional.
12. In case of fire, the crews available on duty will initiate fire fighting actions immediately and simultaneously inform the Delhi Fire Office and occupants / staff for vacating the area under fire.
13. The firm shall depute one Supervisor / qualified Engineer to check the whole system every week for one day and shall maintain a proper record duly signed by them and got countersigned by their visits from the Engineer of the Employer. The firm shall submit a list of persons deployed for the work.

Signature of Tenderer with the seal of the firm

14. **The firm has to arrange for testing both the fire pumps in the presence of Engineer once in a fortnight. The test include running of the pressurization pumping set in case of loss of pressure of fire hydrant system and running of diesel engine pump by artificial closure of electricity. Creating the pressure loss in the pipelines shall test the electricity driven pump set. Test pressure at the farthest end, bottom most ends and at pump delivery. One of the yard hydrants shall also be taped for operation on the same day by creating the desired jet, such test shall be done at least once in a month in the presence of Engineer.**
15. **The firm has to demonstrate to the department proper working of complete automatic fire fighting system by testing the system daily for a period of 45 minutes and also carry out mock drill once in a six month or as & when required by the department. The firm shall be responsible for working conditions of the system all the time and all the parts found defective / damaged have to be replaced free of cost by the firm and in the event of failure of system at the hour of need, firm shall be held responsible and has to meet all the losses.**
16. **The firm shall be responsible for maintaining all accessories, equipment, panels, installed and being operated by them loss or damage of any component, line valves etc. due to faulty operation shall be contractor's responsibility and the contractor shall have to replace the same, make good the damages. In case of hydrant pipes, if the damages are caused due to 3rd party or due to ageing, the decision of the Engineer shall be final with regard to the admissibility of payments towards extra cost of repairs / replacement to the annual maintenance contract.**
17. **The Engineer or his representative shall have access to installation during all hours.**
18. **Maintaining liaison with fire security department in case of fire, test being conducted to check the operation / readiness of the system shall be contractor's responsibility.**
19. **Providing all spares and consumable(Except – Diesel) items of the system shall be contractor's responsibility only.**
20. **Non-availability of competent staff / engineers. Unjustified delay in modification of faults noticed and unsatisfactory maintenance of the complete system shall be treated as a break of contract. Department may consider imposing of suitable penalty or deduction of suitable amount from the payment to be made to the firm in such case. The decision of the department shall be final and binding in this regard.**
21. **The servicing or the firm pumps, jockey pump, motor and engine shall be done twice in a year. During the 1st quarter and 3rd quarter of the contract period to the entire satisfaction of the Engineer nothing extra shall be paid on this account. The water, electricity and diesel will be provided by the department free of cost for its running and maintenance.**
22. **Painting of MS pipes and fittings with synthetic enamel paint if Asian/Berger make related to fire fighting system will be done once in a year.**
23. **I/We agree to pay minimum wages as per the Labor Department Government of Delhi. + PF + ESIC etc. Payment will be made on 7th day of every month.**
24. **Two sets of Uniforms + Identity Card + 1 Pair of Safety Shoes will be given to all the workers within 15 days of award of work and it will be replaced as and when required.**

Signature of Tenderer with the seal of the firm

Institute of Genomics & Integrative Biology
(COUNCIL OF SCIENTIFIC & INDUSTRIAL RESEARCH)
DELHI UNIVERSITY CAMPUS
MALL ROAD, DELHI-110007, INDIA

Part –A (CSIR-IGIB, Mall Road)

Name of Work:- Operation & Comprehensive Maintenance of Fire Alarm and Fire Fighting System at I.G.I.B., Mall Road, Delhi-110007

Sub-Head I

SL. No.	Description of Items	Qty	Unit	Rate (Rs.)	Amount (Rs.)
1	<p>a) Operation and Comprehensive Annual Maintenance Contract of Automatic Fire detection system including repairing & replacement of all defective parts of zonal panels, wiring, speakers, MCB, etc complete in all respect (Except item mentioned at Annexure – I).</p> <p>The list of equipments & accessories of the systems are mentioned below.(We have installed new fire alarm system of Agni make and shall remain under warranty for a period of 16th July 2012.) Being the comprehensive maintenance contract nothing will be paid extra for making the systems functional. Main 16 zone control panel with all accessories including batteries, control cards, LED & switched etc. complete as required – 01 No. Exit Sign Board – 20 Nos. Ionization type smoke detector – 250 Nos. Heat detector – 60 Nos. Response indicator – 66 Nos. Manual call Point – 20 Nos. Hooters – 11 Nos. Battery for panel – 26 Nos.</p> <p>b) Operation and Comprehensive Annual Maintenance Contract of Fire Fighting System:- including control electrical panels, overhauling of motor-pumps including replacement of bearing, automatic water seal, bushes, gland dori etc. complete of main pump, jockey pump & DG operated pump including A, B (Complete kit i.e. filters, oil etc), C and D check of Diesel Engine Set etc. complete in all respect... (Except item mentioned at Annexure – I) Fire Stationary Pump Pump capacity – 47.5 Litre/sec Head – 70 meter Motor Rating – 60 HP, at 415 Volt 3 Ph, 50 Hz. Make – Pump & Motor – Beacon – 02 Nos.</p> <p>Jockey Pump Pump capacity – 6.5 Litre/sec</p>				

Signature of Tenderer with the seal of the firm

<p>Head – 89 meter Motor Rating – 15 HP, 3 Ph, 415 Volt, 50 Hz. RPM -2900 Make – Pump & Motor – Kirloskar – 02 Nos.</p> <p>Diesel Engine Fire Pump Pump capacity – 47.5 Litre/sec Head – 70 meter Engine Rating – 75 BHP, 1500 RPM Make – Beacon – 01 No. Battery for DG set – 2 Nos.</p> <p>Electrical Control Panel Incomer 200 Amp. SFU 4 Pole make L&T – 01 No. Star – Delta starter module with 200 Amp, TPN MCCB make L&T with HRC fuses, Over load Relay, with built in single phase preventer, power and control contractors, Electronic Timer, CT operated ammeter with selector switch ON/OFF push button, R/Y/B phase indication lamps – 01 Nos. Direct online starter module with 100 Amp TP MCCB make L&T with HRC fuses Over load Relay, with built in single phase preventer, power and control contractors, Electronic Timer, CT operated ammeter with selector switch ON/OFF push button, R/Y/B phase indication lamps – 01 Nos. Switch Fused Unit FN63A make L&T – 2 Nos.</p> <p>Yard Hydrant Stand post type hydrant – 8 Nos. Fire hydrant valve – 10 Nos.</p> <p>Hose Reel 20 mm dia bore 30 meter hose pipe – 20 Nos.</p> <p>Hose Pipe 63 mm dia, RRL 15 mt hose pipe – 20 Nos.</p> <p>For Hose Reel Hose cabinet made of 14 guage MS sheet – 8 Nos. Air Release Valve – 2 Nos.</p> <p>Fire Bridge Connection Fire service outlet – 1 No. Fire service inlet – 1 No.</p> <p>Sprinkler System including control electrical panels, overhauling of motor-pumps including replacement of bearing, automatic water pressure switches & gauge, coupling bolts, water seal, bushes, gland dori etc. complete of main fire pump & DG operated pump for sprinkler system including A, B (Complete kit i.e. filters, oil etc), C and D check of Diesel Engine Set etc. complete in all respect... (Except item mentioned at Annexure – I)</p> <p>Diesel engine pump set of Beacon make, 35.9 KW, 1470 RPM – 01 No.</p>				
--	--	--	--	--

Signature of Tenderer with the seal of the firm

	Electrical motor driven pump of Crompton Greaves with motor of 60 HP, RPM – 1450, Head 70m – 01 No. Sprinkler Head 68°C – 80 Nos. Fire Gong Bell – 1 No. Battery for DG sets – 2 Nos. Electrical main control panel along with all accessories including motor starters, HRC fuses, base – carrier, indication lamp and MCCB 200 Amp – 01 No.				
2	Comprehensive maintenance of Fire alarm System				
a)	16- Zone Micro Processor based Fire Alarm Control Panel with power supply and battery charger. Make Agni .				
b)	2- Zone Local Micro Processor based fire Alarm Control Panel with power supply and battery charger. Make: Agni.				
c)	R.O.R. cum Fixed Temperature Heat detector with base for above false ceiling SR 65. Make: Apollo.				
d)	Multi-Criterial combined optical smoke and R.O.R. cum Fixed Temperature Heat Detector with base. Make: Apollo.				
e)	Optical type Smoke Detector with base SR 65. Make: Apollo.				
f)	Medium intensity type hooter cum strobe made out of high quality ABS plastic. Make: Agni.				
g)	Laser Etched LED Base Exit Sign Board Wall/Ceiling mounted with Logo & Arrow on 8 mm +8mm transparent Acrylic sheet of size 220mm X 350mm with extra super bright light LED mounted on Glass Epoxy PCB concealed in top mounted powder coated cabinet and equipped with necessary circuit with Nickel Metal Hydride battery and battery charger. Make: Agni.				
3	Comprehensive maintenance of P.A system				
a)	Voice Alarm Controller for PA system & analog audio inputs/outputs Make: BOSCH	01			
b)	Booster amplifier 240 w (three operational +one standby (Make: Bosch).	04			
c)	6 zones Call Station of zone with zone to make announcements to any pre-assigned zones or to executing pre-defined action incl. a microphone or a flexible stem to transmit speech over the network. (Make: Bosch).	01			
d)	4 watt wall mountable speaker. LS Enclosure (Metal Box) with LMT. (Make: Bosch).	90			
e)	talk back master station panel for public address suitable for 24 talks back (Make Agni)	01			
f)	talk back Unit (Slave Station Simplex) fabricated with 1.66mm thick CRC sheet i/c post offices red paint complete with all accessories (Make Agni)				
	Total for Sl. No. 1-3	12	Per month		

Signature of Tenderer with the seal of the firm

Sub-Head II:- Refilling of Fire Extinguishers.

Sl. No.	Description of Items	Qty	Unit	Rate (Rs.)	Amount (Rs.)
1	Refilling & repainting of CO2, 4.5 KG capacity fire extinguishers including replacing damage discharge horns / pipe and all damages parts etc complete in all respect.	27	Each		
2	Refilling & repainting of water WCO2 of 9 litres capacity fire extinguishers including replacing damage horn / pipe in all damage parts etc complete in all respect.	7	Each		
3	Refilling & repainting of Dry Chemical Powder (ABC) type fire extinguishers of 10 Kg capacity power should be of ISI make including replacing damage discharge horn / pipe and all damages parts etc complete in all respect.	23	Each		
4	Refilling & repainting of Dry Chemical Powder (ABC) type fire extinguishers of 5 Kg capacity including replacing discharge horns and all damages parts, testing etc complete in all respect.	9	Each		
	Total				

Sub-Head-III

Sl. No.	Description of Items	Qty	Unit	Rate (Rs.)	Amount (Rs.)
1	Painting G.I/M.S. pipes and fittings with synthetic enamel paint over a ready mixed priming coat, both of approved quality for new work.				
	i) 25 mm dia MS pipe	160.00	Meter		
	ii) 50 mm dia MS pipe	25.00	Meter		
	iii) 75 mm dia MS pipe	110.00	Meter		
	iv) 100 mm dia MS pipe	30.00	Meter		
	v) 150 mm dia MS pipe	450.00	Meter		
	vi) 200 mm dia MS pipe	17.00	Meter		
	Total				

Signature of Tenderer with the seal of the firm

Part –B (CSIR-IGIB, Mathura Road)

Name of Work:- Operation & Comprehensive Maintenance of Fire Fighting System at I.G.I.B., South Campus, Delhi-110025

Sub-Head I

SL. No.	Description of Items	Qty	Unit	Rate (Rs.)	Amount (Rs.)
1	<p>c) Operation and Comprehensive Annual Maintenance Contract of Fire Fighting System:- including control electrical panels, overhauling of motor-pumps including replacement of bearing, automatic water seal, bushes, gland dori etc. complete of main pump, jockey pump & DG operated pump including A, B (Complete kit i.e. filters, oil etc), C and D check of Diesel Engine Set etc. complete in all respect... (Except item mentioned at Annexure – I) Fire Stationary Pump Pump capacity – 2280LPM Head – 70 meter Motor Rating – 60 HP, at 415 Volt 3 Ph, 50 Hz. Make – Pump & Motor – Kirloskar – 02 Nos.</p> <p>Jockey Pump Pump capacity – 3.5 Litre/sec Head – 70 meter Motor Rating – 7.5 HP,5.5kw,63A, 3 Ph, 415 Volt, 50 Hz. RPM -2900 Make – Pump & Motor – Kirloskar – 02 Nos.</p> <p>Diesel Engine Fire Pump Pump capacity – 47.5 Litre/sec,48.5 kw Head – 70 meter Engine Rating – 60 HP, 1800 RPM Make – Kirloskar – 02 No. Battery for DG set – 2 Nos.</p> <p>Electrical Control Panel Incomer 250 Amp. SFU 4 Pole make L&T – 01 No. Star – Delta starter module with 200 Amp, TPN MCCB make L&T with HRC fuses, Over load Relay, with built in single phase preventer, power and control contractors, Electronic Timer, CT operated ammeter with selector switch ON/OFF push button, R/Y/B phase indication lamps – 01 Nos. Direct online starter module with 100 Amp TP MCCB make L&T with HRC fuses Over load Relay, with built in single phase preventer, power and control contractors, Electronic Timer, CT operated ammeter with selector switch ON/OFF push button, R/Y/B phase indication lamps – 01 Nos. Switch Fused Unit FN63A make L&T – 2 Nos.</p> <p>Yard Hydrant Stand post type hydrant – 10 Nos. Fire hydrant valve – 31 Nos.</p> <p>Hose Pipe</p>				

Signature of Tenderer with the seal of the firm

	<p>20 mm dia bore 30 meter hose pipe – 21 Nos.</p> <p>Hose Reel 63 mm dia, RRL 15 mt hose pipe –62 Nos.</p> <p>For Hose Reel Hose cabinet made of 14 guage MS sheet – 10 Nos. Air Release Valve – 2 Nos.</p> <p>Fire Bridge Connection Fire service outlet – 2 No. Fire service inlet – 2 No.</p> <p>Sprinkler System including control electrical panels, overhauling of motor-pumps including replacement of bearing, automatic water pressure switches & gauge, coupling bolts, water seal, bushes, gland dori etc. complete of main fire pump & DG operated pump for sprinkler system including A, B (Complete kit i.e. filters, oil etc), C and D check of Diesel Engine Set etc. complete in all respect... (Except item mentioned at Annexure – I)</p> <p>Diesel engine pump set of Kirloskar make, 48.5 KW, 1800 RPM – 02 Nos. Electrical motor driven pump of Kirloskar with motor of 60 HP, RPM – 1450, Head 70m – 01 No. Sprinkler Head 68°C – 882 Nos.(ISSH-279 & DG1-603)</p> <p>Battery for DG sets – 2 Nos. Electrical main control panel along with all accessories including motor starters, HRC fuses, base – carrier, indication lamp and MCCB 250 Amp – 01 No.</p>				
	Total	12	Per Month		

Signature of Tenderer with the seal of the firm

Sub-Head II:- Refilling of Fire Extinguishers.

Sl. No.	Description of Items	Qty	Unit	Rate (Rs.)	Amount (Rs.)
1	Refilling & repainting of CO2, 4.5 KG capacity fire extinguishers including replacing damage discharge horns / pipe and all damages parts etc complete in all respect.	39	Each		
2	Refilling & repainting of water of 9 litres capacity fire extinguishers including replacing damage horn / pipe in all damage parts etc complete in all respect.	29	Each		
3	Refilling & repainting of Dry Chemical Powder (ABC) type fire extinguishers of 9 Kg capacity power should be of ISI make including replacing damage discharge horn / pipe and all damages parts etc complete in all respect.	10	Each		
4	Refilling & repainting of Dry Chemical Powder (ABC) type fire extinguishers of 5 Kg capacity including replacing discharge horns and all damages parts, testing etc complete in all respect.	48	Each		
	Total				

Sub-Head-III (Painting)

Sl. No.	Description of Items	Qty	Unit	Rate (Rs.)	Amount (Rs.)
1	Painting G.I./M.S. pipes and fittings with synthetic enamel paint over a ready mixed priming coat, both of approved quality for new work.				
	vii) 25 mm dia MS pipe	50.00	Meter		
	viii) 32 mm dia MS pipe	20.00	Meter		
	ix) 65 mm dia MS pipe	25.00	Meter		
	x) 80 mm dia MS pipe	50.00	Meter		
	xi) 100 mm dia MS pipe	65.00	Meter		
	xii) 150 mm dia MS pipe	120.00	Meter		
	Total				

Signature of Tenderer with the seal of the firm

INSTITUTE OF GENOMICS & INTEGRATIVE BIOLOGY
(Council of Scientific & Industrial Research)
Near Jubilee Hall, University Campus,
Mall Road, Delhi-110007

ABSTRACT OF COST

For Part -A

Name of work:- Operation & Comprehensive Maintenance of Fire Alarm and Fire Fighting System at I.G.I.B., Mall Road, Delhi-110007.

Total cost

Total brought forward from summary

Sub Head – I	Rs
Sub Head – II	Rs
Sub Head – III	Rs
Total	Rs

For Part –B

Name of work:- Comprehensive Maintenance & Operation of Fire Fighting System at I.G.I.B., South Campus, Delhi-110025

Total cost

Total brought forward from summary

Sub Head – I	Rs
Sub Head – II	Rs
Sub Head – III	Rs
Total	Rs
Total of Part A and B	Rs

Rebate (if any)

Rs	
Net Amount	Rs

Note:-

1. Mandatory: Contractor shall quoted rate mentioned in subhead-I breakup should be filled up given in annexure-III on the next page.
2. Quoted rate will remain fixed during 1 year contract period and it should be inclusive of all taxes, minimum wages, ESI, PF, Service tax etc. Nothing shall be given extra apart from the quoted price.

Signature of Tenderer with the seal of the firm

3. The contractor should inspect site, examine specifications schedule of quantities before quoting their rates. The rates given in the schedule of quantities will be deemed to include all the necessary materials, T&P labour required for satisfactory completion of work as shown in the schedule of quantities.

4. All the material shall be of quality specified and approved by the Site Engineer.

Annexure - III

Name of work:- Operation & Comprehensive Maintenance of Fire Alarm and Fire Fighting System at CSIR-IGIB, Mall Road, and Mathura Road Delhi.

Sub Head - I (Breakup Price Per Month)

Sl. No.		Skilled	Unskilled
1	Basic Minimum Wages Skilled @ per month Unskilled @ per month		
2	EPF @ 13.61%		
3	ESI 4.75%		
4	Bonus @8.33%		
	Total		
5	Leave reserve 1/6		
6	Add Cost of Supervisor for 4 days in a month		
	Total of Unskilled, Skilled & Supervisor		
7	Service Tax @ 15%		
	Total		
8	Material Cost (Spare, cleaning and logbooks, diesel for testing etc)		
	Total		
9	Contractor Profit @%		
	Total		

Signature of Tenderer with the seal of the firm

--	--	--	--	--

GENERAL CONDITIONS OF CONTRACT

1. INTERPRETATION

a) In construing these conditions, the Specifications, the Schedule of Quantities, Tender, Special Conditions and Agreement, the following words shall have the meanings herein assigned to them except where the subject or context otherwise requires.

b) This contract shall comprise of the Articles of Agreement, General Conditions of Contract, Special Conditions, Additional Special Conditions, the Schedule of Quantities, Specifications, letter of acceptance of tender and other documents mentioned in the contents sheet attached hereto and including those to which only reference is made herein.

WORK OR WORKS

shall mean all work or works defined in schedule of quantities, specifications and such other work or works as the contractor may be entrusted with for carrying out under this contract.

EMPLOYER: - shall mean Director General, CSIR or any officer authorized by Director General for the purpose.

ENGINEER: - shall mean the Engineer designated by the Employer to superintend and perform other duties as indicated in the contract.

CONTRACTOR: - shall mean the individual or Firm or Company, whether incorporated or not, under- taking the work and shall include the legal personal representative or such individual or the persons composing such Firm or Company or the successors of such Firm or Company and the permitted assignees of such individual or Firm or Firms or Company.

SITE: - shall mean the site of the contract works including any buildings and erections thereon and any other land adjoining thereto (inclusive) as aforesaid allotted by the Employer or the Engineer for the contractor's use.

COMPENSATION: - shall mean all sums payable by way of compensation under any of the conditions shall be considered as reasonable compensation without reference to the actual loss or damage sustained and whether or not any damage sustained, and whether or not any damage shall have been sustained.

Words imputing persons include firms and corporations; words imputing the singular only also include the plural and vice versa where the context so required.

The headings are given to the clauses for convenience and they will not limit the meaning or scope of the clauses in any way.

2. DRAWINGS AND SPECIFICATIONS

The contractor shall execute whole and every part of the work in the most substantial and workmanlike manner both as regards material and otherwise in every respect in accordance with the specifications. The contractor shall also conform exactly and faithfully to the design, drawings and instructions given in the respect of the work by Engineer. The contractor shall be furnished free of charge one copy of such specifications and all such designs, drawings and instructions as are not included in the printed publications.

3. CONTRACTOR TO PROVIDE EVERYTHING NECESSARY

a) **The contractor shall provide at his own cost all materials including cement & steel, plants, tools, appliances, implements, ladders, scaffolding, temporary works, etc. requisite or proper for the execution of the work whether original, altered or substituted and whether included in the specifications or other documents forming part of the contract or which may be necessary for the purpose of satisfying or complying to the requirements of Engineer, as to**

Signature of Tenderer with the seal of the firm

any manner as to which under these conditions he is entitled to be satisfied together with carriage therefore to and from the work. The contractor shall also supply without charge the requisite number of persons with means and materials necessary for the purpose of setting out works and counting, weighing and assisting in the measurement or examination at any time and from time to time of the work or materials. Failing his so doing, the same may be provided by the Engineer at the expense of the contractor and the expenses may be deducted from any money due to the contractor under the contract and / or from his Security Deposit.

b) The contractor shall provide himself with requisite quantity and quality of water for carrying out the works at this own cost. If, however, piped water is supplied by the Employer, the contractor shall pay for the water at one per cent of the total cost of the work done except on Electrical work, Air- conditioning work and Furniture work. The contractor shall make his own arrangement for water connection and laying of further pipelines from the source of supply of the Employer. It should be clearly understood that the Employer does not guarantee to maintain un – interrupted supply of water and it will be incumbent on the part of the contractor to make alternative arrangement for water at his own cost in the event of any temporary break-down in the water mains so that the progress of work is not held up for want of water. No claim as damages or refund of water charges will be entertained on account of such break-downs. However, if the contractor is permitted to make his own arrangement to draw water from a well, hand – pump, or natural river or pond of the Employer, no charges will be made for the water drawn from the same, but the contractor will make good any damage done to the installation and ensure that the quality of water used in the work is confirming to BIS codes and provide for any treatment at his won cost.

c) The contractor shall be allowed to construct temporary wells in Employers' land for taking water for construction purpose only after he has permission of the Employer in writing. This will be subject to the position that NOC for the purpose has been obtained by the contractor from statuary authorities. No charges shall be recovered from the contractor on this account but the contractor shall be required to provide necessary safety arrangement to avoid any accident or damage to adjacent buildings, roads and service lines. He shall be responsible for any accident or damage caused due to construction and subsequent maintenance of the wells and shall restore the ground to its original condition after the wells are dismantled on completion of the work.

d) The Employer on no account shall be responsible for the expenses incurred by the contractor for hired ground or water obtained from elsewhere.

e) Subject to availability the Employer may supply power at only one point from where the Contractor shall make his own cost. These shall be in the custody of the Employer. If there is any hindrance caused to other works the contractor shall reroute or remove such temporary lines without any extra cost. Such temporary lines shall be removed after the completion of work. The cost of power consumed by the contractor shall be payable to the employer at rates fixed by the Employer, which would be deducted from the running account bills. However, the Employer does not guarantee the supply of power and no compensation for any failure or short supply of power shall be entertained.

4. AUTHORITIES, NOTICES & PATENTS

a) The contractor shall conform to any regulation and bye-laws of any corporation and of any electricity supply company and authorities with whose systems the structure is proposed to be connected, and shall before making any variations from the drawing and specifications that may be necessitated for so conforming by giving written notice to the Engineer specifying the variations proposed to be made, the reasons for making it and apply for instructions thereon. If the compliance with this clause involves any extra work not included in this contract, he shall specify these items of work and the allowance of extra payment required on their account.

b) The contractor shall give all notices required by the said regulations or bye-laws to be given to any Authority and pay to such Authority or to any public office all fees that may be chargeable in respect of the works and lodge the receipts with the bill to the Engineer for reimbursement.

5. RATES TO INCLUDE ALL TAXES

a) Rates quoted by the contractor shall include sales tax, duties, octroi, toll tax, royalties and all other taxes in respect of this contract and the Employer shall not entertain any claim whatsoever in this respect. Tendered rates are inclusive of all taxes and levies payable under the respective statutes. However pursuant to the Constitution (Forty

Signature of Tenderer with the seal of the firm

Sixth Amendment) Act, 1982 if any further tax or levy is imposed by Statutes, after the date of receipt of tenders and the contractor thereupon necessarily and properly pays such taxes / levies the contractor shall be reimbursed the amount as per the rules on producing proof of payment so made provided such payments, if any, is not in the opinion of the Employer (whose decision shall be final and binding) attributable to delay in executing of work within the control of the contractor.

b) The contractor shall keep necessary books of accounts and other documents for the purpose of this condition as may be necessary and shall allow inspection of the same by a duly authorized representative of the Employer and further shall furnish such other information and documents as the Employer may require.

c) The contractor shall within a period of thirty days of imposition of any further tax or levy pursuant to the Constitution (Forty Sixth Amendment) Act, 1982 give a written notice thereof to the Employer that the same is given pursuant to this condition together with all necessary information relating thereto.

d) SUFFICIENCY OF TENDER

The contractor shall be deemed to have satisfied himself before tendering as to the correctness and sufficiency of the tender for the works and the rates and the prices quoted in the schedule of items, which rates and the prices shall, except as otherwise provided, cover all his obligations under the contract and all matters and things necessary for the proper completion and maintenance of the works.

6. MATERIALS

a) If the specification of schedule of items provide for the use of any material to be supplied by the Employer's stores or if it is required that the contractor shall use certain stores to be provided by the Employer as shown in the schedule of materials hereto annexed, the contractor shall be bound to procure and shall be supplied such materials and stores as are from time required to be used by him for the purpose of the contract only and value of the materials supplied at the rates specified in the said schedule of materials and of the quantities incorporated in the work may be set off or deducted from any sums then due, or thereafter to become due to the contractor under the contract or otherwise or against or from the Security deposit. All materials so supplied to the contractor by the Employer shall remain the absolute property of the Employer and the contractor shall be the trustee of the materials so supplied / procured and the said materials shall not be removed / disposed off from the site of the work on any account and shall be at all times open for inspection by the Engineer of Employer. The contractor shall bear all incidental charges for cartage, storage and safe custody of all materials and against damage due to dampness, rain, sun, fire and theft and be fully responsible for their storage and maintenance. Any such material unused and in perfectly good condition in the opinion of the Employer at the time of the completion of work or termination of the contract, or earlier shall be returned to the Employer at a place directed by Engineer at contractor's cost and at rates stipulated in the said schedule but in case the Employer decides not to take back the materials the contractor shall have no claim for compensation on account of any such materials supplied to him as aforesaid being unused by him or for any wastage or damage to any such materials.

b) If for any reason there is delay or non-supply of material as shown in the schedule, the contractor shall procure the same and complete the work in time after due intimation and approval of the Employer. The difference in price (between his procurement price and price shown in the schedule) shall be paid to the contractor. However in case approval of the Employer is not given, only suitable extension of time would be considered and no other claim of compensation / damages shall be payable by the Employer.

c) After completion of the work or on determination / termination of the contract, the theoretical quantity of cement to be used in work shall be calculated on the basis of statement showing quantity of cement to be used in different items of work provided in current Schedule for the purpose printed by CPWD. In case any item is executed for which the standard constants for the consumption of cement are not available in the above mentioned statement or cannot be derived from this statement, the same shall be calculated on the basis of standard formula to be laid down by the Engineer. Over this theoretical quantity of cement, shall be allowed a variation up to 3% plus/minus for works estimated cost of which as put to tender is more including authorized variation, if not returned by the contractor, shall be recovered at twice the issue rate, without prejudice to the provision of other conditions regarding return of materials governing the contract. In the event of its being discovered that the quantity of cement which is less than the quantity ascertained as herein before provided (along with variation on minus side as stipulated above) the cost of quantity of cement not so used, shall be recovered from the contractor on the basis of stipulated issue rates and

Signature of Tenderer with the seal of the firm

cartage to site.

d) The provision of foregoing sub-clause shall apply Mutatis-Mutandis in the case of steel reinforcement or structural steel sections (each diameter/section or category shall be considered separately) except that the theoretical quantity of the steel shall be taken as the quantity required as per design or as authorized by the Engineer, including lappages, plus 3% wastage due to cutting into pieces. Over this theoretical quantity 2% plus/minus shall be allowed as variation due to wastage.

e) The provision of foregoing sub-clause shall apply Mutatis – Mutandis in the case of cables (other than under – ground cables), wires, conduits / GI pipes, GI/MS sheets used in various items of work shall be calculated on the basis of measurements recorded in the measurement books for the purpose of payment and for assessing the consumption of materials used in the works. Over this quantity a variation of 5% plus shall be allowed for wastage of materials during execution in case of cables (other than under – ground cables), wires, conduits/GI pipes, and 10% plus in case of GI/MS sheets.

f) The provisions made above are without prejudice to the right of the Employer to take action against the contractor under the conditions under the contract for not doing the work according to the prescribed specifications.

g) In case of easy availability of approved quality of cement and steel in the open market it will be Employer's discretion to make these items as contractor's supply.

7. TESTING OF MATERIALS

The contractor shall provide assistance, instruments, materials, labour and any other arrangement normally required for testing, checking of materials and workmanship as stipulated in the specifications and by statutory authority at his own cost. The Employer has the right to appoint the testing authorities. In case Engineer desires testing of materials from the testing authorities the contractor shall arrange for the same. The testing fee of the testing authorities shall be borne by the Department, if the tested materials are found to be conforming to laid down specifications. In case after testing the materials are not found as per specifications then the testing fee shall be borne by the contractor. Failing his so doing, the same shall be provided by the Engineer at the expense of the contractor and the expenses shall be deducted from any money due to the contractor under the contract and / or from the Security Deposit or proceeds thereof or of a sufficient portion thereof.

8. CONTRACTOR'S ENGINEERS / FOREMAN & WORKMEN

a) The contractor shall give all necessary personal superintendence during the execution of the work and as long as thereafter as the Engineer may consider necessary until the expiration of the Defects Liability Period. The contractor shall employ competent Site Engineer/ Foreman as detailed in "special conditions" and as approved by the Engineer whose qualification must conform to be requirement specified by the Engineer who shall be constantly in attendance of the work while the men are at work. Any directions, explanations, instructions or notices given by the Engineer to such Site-Engineer or Foreman or any other authorized agent shall be held to be given to the contractor. In case contractor fail to provide engineering personnel as given in special conditions, the Employer shall have right to appoint the necessary engineering personnel requisite staff needed for proper Superintendence of work at the cost of contractor for the period of currency of contract inclusive of defect liability period.

b) The contractor shall on the request of the Engineer immediately dismiss from the works any person employed thereon who may in the opinion to the Engineer be unsuitable or incompetent or who may in the opinion of the Employer misconduct himself.

9. ACCESS

a) The Engineer, and the Employer or its representative shall at all reasonable time have free access to the works and / or workshops, factories or other places the material are being prepared or constructed for the contract and also to any place where the materials are lying or from which they are being obtained and the contractor shall give every facility to them for inspection. Except the representatives of statutory authorities and those mentioned above no

Signature of Tenderer with the seal of the firm

other person shall be allowed on the works at any time without the permission of the Engineer.

b) If any work is to be done at a place other than the site of works, contractor shall obtain written permission of the Engineer.

10. VARIATION & PRICE FOR VARIATION

- a) The Engineer with the approval of the Employer shall have power to make any alteration / omissions / additions and / or substitutions from the original specifications, drawings, designs, and written instructions and such alterations, omissions, additions, substitutions shall not invalidate the contract and any altered, additional, or substituted work which the contractor may be directed to do in the manner specified above as part of the work shall be carried out by the contractor on the same conditions in all respects on which he agreed to do the main work subject to the variation limits prescribed hereunder. In case deviations of agreement quantities exceed the prescribed limits, then the rates for quantities exceeding the prescribed limits shall be determined on market rate basis. The rates for such altered, additional or substituted work under this clause shall be worked out in accordance with the following provisions in their respective order!.
- b) If the rates for the altered, additional, or substituted work are specified in the contract for the work, the contractor is bound to carry out the altered, additional, or substituted work at the same rates as are specified in the contract for the work.
- c) If the rates for the altered, additional, or substituted work are not specifically provided in the contract for the work, the rates will be derived from the rates for a similar class of work as are specified in the contract for the work.
- d) If the rates for the altered, additional, or substituted work cannot be determined in the manner specified in sub-clause (b) and (c) above, then the contractor shall, within 10 working days from the date of receipt of the order to carry out the work through notice in writing, inform the Engineer of the rate which it is his intention to charge for such class of work, supported by analysis of the rate claimed which shall be based on actual cost of work plus 10% as contractor's profit and over – heads except in case of departmental materials for which contractors profit and over- heads shall be 2.5 %. When such notice has been given, the Engineer with the consent of the Employer may agree to such a rate but if the Engineer does not agree to the contractor's rate the Engineer may cancel his order to carry out such class of work and arrange to carry out in such a manner as he may consider advisable.
- e) Under no circumstances, the contractor shall suspend the work on the plea of non-settlement of rates of items falling under the clause.
- f) Variation limits prescribed is as under:
- | | |
|------------------------------------|------|
| (i) Building work | 30% |
| (ii) Maintenance / Emergency works | 50% |
| (iii) Foundations works | 100% |
| (iv) Services works | 30% |

11. FAULTY MATERIALS, WORKMANSHIP & DEFECTS AFTER COMPLETION

a) The Engineer shall have powers to require the removal from the site of all materials and work which in his opinion are not in accordance with specifications and in case of default, the Engineer shall be at liberty to employ other persons to remove the same without being answerable or accountable for any loss or damage that may happen or arise to such materials to be substituted thereof and in case of default the Engineer may cause the same to be supplied and all costs which may attend such removal and / or substitution are to be borne by the contractor.

b) If it shall appear to the Engineer or to the Employer based on audit / technical examination that any work has been executed with unsound, imperfect, or unskillful workmanship or with materials of any inferior description, or that any materials or articles provided by him for the execution of the work are unsound or of a quality inferior to that

Signature of Tenderer with the seal of the firm

contracted for or otherwise not in accordance with the contract, any defects, shrinkage or other faults which may appear within the defects liability period of twelve months from the date of completion arising in the opinion of the Engineer, the contractor shall on demand in writing which shall be made within twelve months of the completion of the work from the Engineer specifying the work, materials, articles defects or other faults complained of notwithstanding that the same may have been passed, certified and paid for, forthwith rectify, or remove and reconstruct the work so specified in whole or in part, as the case may require or as the case may be, remove and reconstruct the work so specified in whole or in part, as the case may require or the case may be, remove the materials or articles so specified and provide other proper and suitable materials or articles at his own cost. In case of any such failure, the Engineer may rectify or remove or re-execute the work or remove and replace with others, the material or articles complained of as the case may be at the risk and cost in all respects of the contractor.

c) In lieu of rectifying the work not done in accordance with the contract, the Employer may, allow such work to remain, and in that case make allowance for the difference in value, together with such further reduction as in his opinion may be reasonable. However, this will not cover those works which are not technically acceptable.

d) Provided always that nothing in this clause shall relieve the contractor from his liability to execute the works in all respects in accordance with the terms and conditions of this contract, or from his liability to make good all defects.

12. WORKS TO BE OPEN FOR INSPECTION

a) All work during course of execution or executed in pursuance of the contract shall at all times be open to the inspection and supervision of the Engineer and the contractor shall at all times during the usual working hours, and at all other times at which reasonable notice of the intention of the Engineer to visit the works shall have been given to the contractor, either himself be present to receive order and instruction or have a responsible agent duly accredited in writing present for that purpose and shall made all arrangements inclusive of excavation & dismantling, if required.

b) The contractor shall give not less than seven days notice in writing to the Engineer before covering up or otherwise placing beyond the reach of measurement any work in order that the same may be measured and correct dimensions thereof be taken before the same is so covered up or placed beyond the reach of measurement and shall not cover up and place beyond the reach of measurement, any work without the consent in writing of the Engineer and the Engineer shall within the aforesaid period of seven days inspect the work, and if any work shall be covered up or placed beyond the reach of measurement without such notice having been given or the Engineer's constant obtained the same shall be uncovered at the contractors expense or in default thereof no payment or allowance shall be made for such work or the materials with which the same was executed.

13. ASSIGNMENT OR SUB-LETTING

a) The contract shall not be assigned or sublet without the written approval of the Employer. And if the contractor shall assign or sub-let his contract or attempt to do so or become insolvent or commence any insolvency proceedings or make any composition with his creditors or attempt to do so or if any bribe, gratuity or gift, loan, perquisite, reward or advantage pecuniary or otherwise, shall either directly or indirectly, be given, promised or offered by the contractor or any of his servants or agents to any person in the employment of the Employer in any way directly or indirectly interested in the contract, the Employer shall have the power to adopt any of the courses specified under clause – 23 as may be best suited to the interest of the Employer and in the event of any of the courses being adopted the consequences specified in the said clause shall ensure.

b) Where the contractor is a partnership firm, the approval in writing of the Employer shall be obtained before any changes in the constitution of the firm. Where the contractor is an individual or a Hindu undivided family business concern such approval as aforesaid shall likewise be obtained before the contractor enters into any partnership agreement hereunder the partnership firm would have the right to carry out the work be deemed to have been assigned or sublet in contravention of clause 13 (a) and the same action may be taken and the same consequences shall ensue as provided in the said clause 13 (a).

Signature of Tenderer with the seal of the firm

14. INDEMNIFYING AGAINST DAMAGES TO PERSONS, PROPERTY & STATUTES

The contractor shall take all precautions to avoid all accidents by exhibiting necessary caution boards day and night, speed limit boards, red flags, red lights, and providing barriers. He shall be responsible for all damages and accidents caused due to negligence on his part. No hinderance shall be caused to traffic during the execution of work.

a) The contractor shall be responsible for all injury to persons, animals or things, and for all damage, whether such injury or damage arises from carelessness or accident in any way connected therewith. This clause shall be held to include interlia any damage due to causes as aforesaid to work, building (whether immediately adjacent or otherwise) and to roads, streets, foot paths, bridges or ways as well as all damage caused to the buildings and works forming the subject of this contract by inclemency of weather. The contractor indemnifies the Employer and holds him harmless in respect of all expenses arising from such injury or damages as aforesaid and also in respect of any award of compensation or damage consequent upon such claim including legal costs.

b) The contractor shall reinstate all damage of every sort mentioned in this clause, so as to deliver the whole of the contracted works complete and perfect in every respect and so as to make good and otherwise satisfy all claims for damage as aforesaid to the property of third parties.

c) The contractor also indemnifies the Employer against all claim which may be made upon the Employer for acts during the currency of this contract by any employee or representative of an employee of the contractor or any sub-contractors, employed by him, for any injury to or loss or life, of such employees, or for compensation payable under any law for the time being in force to any workmen or to the representative of any deceased or incapacitated workmen.

d) The contractor also indemnifies the Employer against all claims which may be made upon the Employer for acts during the currency of this contract by the Central / State Government or local Municipal authorities for the noncompliance of any laws, regulations, rules pertaining to wages act, safety act in force and any amendments thereof in respect of all labour and apprentices directly or indirectly employed in the work under this contract.

e) The Employer shall be at liberty and is hereby empowered to deduct the amount of any damages, compensation costs, charges and / or expenses arising or accruing from or in respect of any such claim and / or damages as aforesaid from any sum or sums due to become due to the contractor or security deposit.

f) The contractor shall indemnify the Employer against any action, claim or proceedings relating to infringement or use of any patent or design or any alleged patent or design rights and shall pay any royalties which may be payable in respect of any article or part thereof included in the contract. In the event of any claims made under or action brought against the Employer in respect of any such matters as aforesaid the contractor shall be immediately notified thereof and the contractor shall be at liberty, at his own expense, to settle any dispute or to conduct any litigation that may arise therefore. Provided that the contractor shall not be liable to indemnify the Employer if the infringement of the patent or design or any alleged patent or design right is the direct result of an order passed by the said Employer or his authorized representative.

15. LIEN IN RESPECT OF CLAIM IN OTHER CONTRACTS

a) Any sum of money due and payable to the contractor including the security deposit under the contract may be withheld or retained by way of lien by the Employer or Government or any other contracting person or persons against any claim of the Employer or Government or such other persons in respect of payment of a sum of money arising out of or under any other contract made by the contractor with the Employer or Government or with such other persons.

b) It is agreed term of the contract that the sum of money so withheld or retained under this clause by the Employer will be kept withheld or retained as such by the Employer or till his claim arising out of in the same contract or any other contract is either mutually settled or determined by the Arbitrator if the contract is governed by arbitration clause or by the competent court as the case may be, and that the contractor shall have no claim for interest or damages whatsoever on this account or any other ground in respect of any sum of money withheld or retained under this clause and duly notified as such to the contractor.

Signature of Tenderer with the seal of the firm

16. WITHHOLDING & LIEN IN RESPECT OF SUMS CLAIMED

a) Whenever any claim or claims for payment of a sum of money arises out of or under the contract against the contractor, the Employer shall be entitled to withhold and also have a lien no retain such by or sums in whole or in part from the security deposit, if any furnished as the case may be and also have a lien over the lien over the same pending finalization or adjudication of any such claim. In the event of the security deposit being insufficient to cover the claimed amount or amounts or if no security deposit has been taken from the contractor, the Employer shall be entitled to withhold and have a lien to retain to the extent of such claimed amount or amounts referred to above, from any sum or sums found payable or which at any time thereafter may become payable to the contractor under the same or any other contract, with the Employer or any contracting person pending finalization or adjudication of any such claim.

It is an agreed term of the contract that the sum of money so withheld or retained under the lien referred above, by the Employer will be kept withheld or retained as such by the Employer till the claim arising out of or under the contract is determined by the Arbitrator (if the contractor is governed by the arbitration clause) or by the competent court as the case may be and that the contractor will have no claim for interest or damages whatsoever on any account in respect of such withholding or retention under the lien referred to above and duly notified as such to the contractor. For the purpose of this clause, where the contractor is a partnership firm or a limited amount or amounts in whole or in part from any sum payable to any Partner / Limited company as the case may be, whether in his individual capacity or otherwise.

b) The Employer shall have the right to cause an audit and technical examination of the works and the final bills of the contractor including all supporting vouchers, abstract etc., to be made after payment of the final bill and if as a result of such audit and technical examination any sum is found to have been over paid in respect of any work done by the contractor under the contract or any work claimed by him to have been done by him under the contract and found not to have been executed the contractor shall be liable to refund the manner prescribed in sub-clause (a) of this clause or in any other manner legally permissible; and if it is found that the contractor was paid less than what was due to him under the contract in respect of any work executed by him under it, the amount of such under-payment shall be duly by the Employer to the contractor. Provided that the Employer shall not be entitled to recover any sum over-paid, nor the contractor shall be entitled to payment of any sum paid short where such payment has been agreed upon between the Employer on the one hand and the contractor on the other hand, under any term of contract permitting payment for work after assessment by the Employer.

17. IN-CASE OF DEATH OF CONTRACTOR

Without prejudice to any of the rights or remedies under this contract, if the contractor dies, the Employer shall have the option of terminating the contract without compensation to the contractor.

18. SUB-CONTRACTORS

The Employer reserves the right to use the premises and any portion of the site for the execution of any work not included in the contract. The contractor is to afford all reasonable facilities to all sub-contractors, specialists, merchants, tradesman and others who may at any time be appointed by the Employer for executing any work or supplying any goods relating to the constructions, servicing, equipping or furnishing of the work under this contract.

19. COMPLIANCE TO LABOUR LAWS & APPRENTICE ACT

The contractor shall comply with all the provisions of the Minimum Wages Act, 1948, Contract Labour (Regulation and Abolition) Act, 1970, and rules and orders framed there under and other labour laws affecting contract labour and Apprentice Act, 1961 and rules and orders framed there under that may be in force or brought into force from time to time. Contractor shall obtain a valid license under Contract Labour (R & A) Act 1970 and Contract Labour (R & A) Central Rules 1971 before commencing work and which should be valid till the completion.

20. LIQUIDATED DAMAGES AND COMPENSATION FOR DELAY

a) The time for carrying out the work as entered in the tender shall be strictly observed by the contractor and shall be

Signature of Tenderer with the seal of the firm

deemed to be the essence of the contract on the part of the contractor. The work shall throughout the stipulated period of the contract be proceeded with all due diligence and the contractor shall pay as compensation an amount equal to half per cent or such smaller amount as the Employer (whose decision in writing shall be final) may decide on the amount of the whole work as shown in the agreement, for every week that the work remains uncompleted or unfinished after the proper dates subject to a maximum of 10% of the contract value.

b) And further to ensure good progress during the execution of the work, the contractor shall be bound in all cases in which the time allowed for any work exceeds one month (save for special jobs) to complete one – eight of the whole of the work before one-fourth of the whole time allowed under the contract has elapsed; three-eighths of the work before one-half of such time has elapsed, and three-fourths of the work before three – fourths of such time has elapsed. However for special jobs if a time schedule has been submitted by the contractor and the same has been accepted by the Employer, the contractor shall comply with the said time schedule. In the event of the contractor failing to comply with this condition, he shall be liable to pay as compensation an amount equal to half per cent or such smaller amount as the Employer (whose decision in writing shall be final) may decide on the said cost of the work for every week that the due quantity of work remains incomplete. Provided that the entire compensation to be paid under the provisions of this clause shall not exceed ten per cent on the cost of the work as shown in the agreement.

Contractor shall pay as compensation an amount equal to half percent (0.50%) or such smaller amount as the Employer (whose decision in writing shall be final) may decide on the cost of the whole work as shown in the agreement, for every week the work remains uncompleted or unfinished or due quantity of work remains incomplete after the proper dates. Compensation to be paid shall not exceed ten per cent of the cost of the work as shown in the agreement.

21. DAMAGE TO WORKS IN CONSEQUENCE OF HOSTILITIES OR WAR – LIKE OPERATIONS

a) The work (whether fully constructed or not) and all materials, tools, and plants, scaffolding, temporary buildings and other things connected therewith shall be at the risk of the contractor until the work has been delivered to the Employer and a certificate from him to that effect obtained. In the event of the work or any materials properly brought to the site for incorporation in the work being damaged or destroyed in consequence of hostilities or war-like operation, the contractor shall, when ordered in writing by the Employer, remove any debris from the site, collect and properly stack or remove in store all serviceable materials salvaged from the damaged work and shall be paid at the contract rates in accordance with the provision of this agreement for the work of clearing the site of debris, stacking, removal of serviceable materials and for the reconstruction of all works ordered by the Employer such payment being in addition to compensation up to the value of the work originally executed before being damaged or destroyed and not paid for. In case of works damaged or destroyed but not already measured and paid for the compensation shall be assessed by the Employer. The contractor shall be paid for the damage / destruction suffered and for restoring the material at the rates based on the analysis of rates tendered for in accordance with the provision of this agreement. The certificate of the Employer regarding the quality and quantity of materials and the purpose for which they were collected shall be final and binding on the contractor.

b) Provided always that no compensation shall be payable for any loss in consequence of hostilities or war-like operation (i) unless the contractor had taken all such precautions against Air Raid as are deemed necessary by the A.R.P. Officers or the Employer, (ii) for any materials etc., not on the site of the work or for any tools and plant, machinery, scaffolding, temporary buildings and other things not intended for the work.

c) In the event of the contractor having to carry out reconstruction as aforesaid, he shall be allowed such extension of time for its completion as is considered reasonable by the Employer.

22. EXTENSION OF TIME

a) If the contractor shall desire an extension of time for the completion of the work on the grounds of his having been unavoidably hindered in its execution or any other ground, he shall apply in writing to the Employer within thirty days of the date of hindrance on account of which he desires extension as aforesaid, and the Employer shall, if in his opinion (which shall be final) reasonable grounds shown therefore, authorize such extension of time if any, which may, in this opinion, be necessary or proper.

Signature of Tenderer with the seal of the firm

b) In the event, the value of work exceeds the value of the Bill of Quantities owing to variations the contractor shall be entitled to ask for extension of time in proportion to the increased value of work.

c) In case of performance security forming part of security deposit which are permissible in the form of bank guarantee then the contractor make a request for extension of time only after the firm has got validity of Bank Guarantee extended suitably.

23. SUSPENSION OF WORK BY CONTRACTOR

The Employer may without prejudice to his right against the contractor in respect of any delay or inferior workmanship or otherwise or to any claims for damages in respect of any breaches of the contract and without prejudice to any rights or remedies under any of the provisions of this contract or otherwise and whether the date for completion has or has not elapsed by notice absolutely determine the contract in any of the following cases:

- (ii) If the contractor having been given by the Engineer a notice to rectify, reconstruct or replace any defective work or that the work is being performed in any inefficient or otherwise improper or unworkman - like manner shall omit to comply with the requirements or such notice for a period of seven days thereafter or if the contractor shall delay or suspend the execution of the work so that in the judgment of the Employer (which shall be final and binding) he will be unable to ensure completion of the work by date for completion or he has already failed to complete the work by that date.
- (iii) If the contractor being a company shall pass a resolution or the court shall make an order that the company shall be wound up or if a receiver or a manager on behalf of a creditor shall be appointed or if circumstances shall be wound up or if a receiver or a manager on behalf of a creditor shall a appointed or if circumstances shall arise which entitle the court of creditor to appoint a receiver or a manager or which entitle the court to make a winding up order.
- (iv) If the contractor commits breach of any of the terms and conditions of this contract.
- (v) If the contractor commits any acts mentioned in Clause – 13 hereof.

When the contractor has made himself liable for action under any of the cases aforesaid, the Employer shall have the following powers:

- (i) To determine or rescind the contract as aforesaid (of which termination or rescission notice in writing to the contractor under the hand of the Employer shall be conclusive evidence). Upon such determination or rescission the security deposit of the contractor shall be liable to be forfeited and shall be absolutely at the disposal of the Employer.
- (ii) The Engineer may employ labour paid by the Employer and to supply materials to carry out the work or any part of the work debiting the contractor with the cost of the labour and the price of the materials (of the amount of which cost and price certified by the Engineer shall be final and conclusive against the contractor) and crediting him with the value of the work done in all respects in the same manner and at the same rates as if it had been carried out by the contractor under the terms of his contract. The certificate of the Engineer as to the value of the work done shall be final and conclusive against the contractor, provided always that action under the sub-clause shall only be taken after giving notice in writing to the contractor. Provided also that if the expenses incurred by the Employer are less than the amount payable to the contractor at his agreement rates, the difference should not be paid to the contractor.
- (iii) After giving notice to the contractor to measure up the work of the contractor and to take such part thereof as shall be unexecuted out of his hands and to give it to another contractor to complete in which case any expenses which may be incurred in excess of the sum which would have been paid to the original contractor if the whole work had been executed by him (of the amount of which exceed the certificate in writing of the Engineer shall be final and conclusive) shall be borne and paid by the original contractor and may be deducted from any money due to him by the Employer under his contract or any other account whatsoever or from his security deposit.
- (iv) In the event any one or more of the above courses being adopted by the Employer the contractor shall have no claim to compensation for any loss sustained by him by reason of his having purchased or procured any

Signature of Tenderer with the seal of the firm

materials or entered into any engagements or made any advances on account or with a view to the execution of the work or the performance of the contract. And in case action is taken sum for any work thereof or actually performed under this contract unless and until the Engineer has certified in writing the performance of such work and the value payable in respect thereof and he shall only be entitled to be paid the value so certified.

24. SECURED ADVANCE

The contractor on signing an indenture in the form specified by the Employer during the progress of the execution of the work may be paid if agreed by the Employer up to 75 per cent of the estimated value which shall take into account the market value and contractor's tendered rates for the finished item of any material which in the opinion of the Engineer is likely to be incorporated in the work within next three months, are non-perishable and are in accordance with the contract and which have been brought on the site in connection therewith and are adequately stored and protected against damage by weather or other causes but which have not at the time of advance been incorporated in the works. When materials on account of which advance has been made under this clause are incorporated in the work the amount of such advance shall be deducted from the next payment made under any of the clause or clauses of this contract.

25. MOBILIZATION ADVANCE

In specialized and Capital intensive works costing not less than Rs.2 crores, mobilization advance limited to a maximum of 10% of the tendered value of Rs. 1 crore whichever is less is payable in two equal installments at 10% simple interest.

If Mobilization advance should be given, it should expressly stated in the NIT/Bid documents, indicating the amount, rate of interest and submission of Bank Guarantee of equivalent amount. The advance payment may be released in stages depending upon the progress of the work and mobilization of required equipment etc. There should be a provision in the contract for adjustment of advance progressively even as the bills are cleared for payment.

The recovery of mobilization should start when 10% of the work is executed and recovery of total advance should be completed by the time 80% of the original contract price is executed.

26. CERTIFICATES & PAYMENTS

a) No payments shall be made for a work estimated to cost Rupees ten thousand or less till the whole of the work shall have been completed and certificate of completion given. But in the case of a work estimated to cost more than Rupees ten thousand, the contractor shall, on submitting the bill be entitled to receive a monthly payment proportionate to the part of work executed, and to the satisfaction of the Engineer, whose certificate of the sum so payable shall be final and conclusive against the contractor, provided the amount of work done is as per the value of intermediate certificate or for a lesser amount at the discretion of the Engineer as mentioned in the NIT. All such intermediate payments for work actually done and completed and shall not preclude the requiring of bad, unsound, imperfect or unskilled work to be removed and taken away and reconstructed, or rejected or be considered as an admission of the due performance of the contract, of any part thereof in any respect or the accruing of any claim nor shall it conclude, determine, or affect in any way the powers of the Employer under these conditions or any of them as to the final bill shall be submitted by the contractor within two months of the date fixed for the completion of work or of the date of the certificate of completion furnished by the Employer and payment shall be made within three months if the value of the completed works is up to Rs. Two lakhs and in six months if the same exceeds Rs. Two lakhs of the submission of such bill. If there shall be any dispute about any item or items of the work then the undisputed item or items only shall be paid within the said period of three months or six months as the case may be.

b) Whenever there is likely to be delay in recording detailed measurements for making a running payment, advance payment without detailed measurement for work done worked out at 75 per cent of the tendered rates for assessed quantities may be made in running account bills by the employer on the basis of a certificate from the Engineer. The advance payments so allowed shall be adjusted in the subsequent running bills by taking detailed measurements thereof. Final payments shall be made only on the basis of detailed measurements.

c) A bill shall be submitted by the contractor each month on or before the date fixed by the Engineer on printed forms

Signature of Tenderer with the seal of the firm

obtainable from the Engineer's office. The Engineer shall take or cause to be taken the requisite measurements for the purpose of having the same verified and the claim, as far as admissible, adjusted as far as possible, before the expiry of ten days from the presentation of the bill. If the contractor does not submit the bill within the time fixed as foresaid the Engineer may cause action within seven days of the date fixed as aforesaid, an authorized representative to measure up the said work in the presence of the contractor whose signature to the measurement will be sufficient warrant and the Engineer may prepare the bill from such measurements.

d) Before taking any measurement of any work the Engineer or his authorized representative deputed by him shall give reasonable notice to the contractor. If the contractor fails to attend such notice or fails to sign or to record the difference within a week from the date of measurement in the manner required by the Engineer then in any such event the measurement taken by the Engineer or by the authorized representative deputed by him as the case may be, shall be final and binding on the contractor and the contractor shall have no right to dispute the same.

e) The charges in the bills shall always be entered at the rates specified in the agreement or in the case of any extra work ordered in pursuance of these conditions and not mentioned or provided for in the agreement at the rate determined as per clause – 10. However in case or partially executed items of work, the Employer at his discretion allows proportionate rates for such items as determined by the Engineer whose certificate of the sum so payable shall be final and conclusive against the contractor.

27. SECURITY DEPOSIT

a) A sum @ 10% of the gross amount of the bill shall be deducted from each running bill of the contractor till the sum along with the sum already deposited as earnest money, will amount to security deposit of 5% of the tendered value of the work. In addition, the contractor shall be required to deposit an amount equal to 5% of the tendered value of the contract as Performance Security within the period prescribed for commencement of work in the letter of award issued to him.

b) In case a fixed deposit receipt of any scheduled bank is furnished by the contractor to the Employer as part of the security deposit and the bank goes into liquidation or for any reasons is unable to make payment against the said fixed deposit receipt, the loss caused thereby shall fall on the contractor and the contractor shall forthwith on demand furnish additional security deposit, provided always that the Employer for this purpose shall be entitled to recover the said percentage of the amount from each running bill till the balance of the amount of security deposit is realized. All compensation or the other sums of money payable by the contractor under the terms of this contract may be deducted from the security deposit or from the interest arising there from or from any sums which may be due to or may become due to the contractor by the Employer on any account whatsoever and in the event of his security deposit being reduced by reason of any such deductions aforesaid, the contractor shall within ten days make good in cash or further fixed deposit receipt pledged in favour of the Employer. The security deposit shall be collected from the running bills of the contractor at the rates mentioned above and the earnest money if deposit at the time of tenders will be treated as part of the security deposit.

c) The contractor if he so desires may furnish fixed deposit receipt in advance towards the security deposit. Such fixed deposit receipt shall be of a minimum value of Rs 25000/- each (The last such fixed deposit receipt could be of a lower value on the basis of the amount). In case any recovery is affected from running account bills, such recovered amount shall not be replaced with fixed deposit receipt. It is in the contractor's interest to keep a watch about the adequacy of the fixed deposit receipt submitted.

d) No partial refund of security deposit shall be made during the defect liability period. In case the final bill is not settled within stipulated period for reasons beyond control and the Employer is satisfied that the security deposit is not required for adjustment of Employers dues or whatsoever dues either in this or any other contract then this security deposit either in full or in part could be refunded at the sole discretion of the Employer. However, release of security deposit would be only after written clearance of Labour Officer regarding no dues or claims is received.

e) In case of termination of contract, this security deposit shall be forfeited and amount necessary to make up this amount shall be recovered from money due to the contractor under this contract, or any other contract with the Employer.

f) PERFORMANCE SECURITY

Signature of Tenderer with the seal of the firm

i) The contract shall be required to deposit an amount equal to 5% of the tendered value of the contract as Performance Security within the period prescribed for commencement of work in the Letter of Award issued to him. Performance security may be accepted as Bank Guarantee of Scheduled Banks and State Bank of India or in cash or in the form of Fixed deposit Receipts pledges in favour of the Employer.

ii) The contractor shall submit an irrevocable PERFORMANCE GUARANTEE of 5% (five percent) of the tendered amount in addition to the Security Deposit of 5% (Five percent) for his proper performance of the contract agreement (not with standing and/or without prejudice to any other provisions in the contract) within in the period prescribed for commencement of work in the Letter of Award issued to him.

This guarantee shall be in the form of fixed deposit receipts pledges in favour of the Employer or Bank guarantee of Scheduled Banks or State Bank of India in accordance with the Proforma attached. In case fixed deposit receipts of any bank are furnished by the contractor to Employer as part of the Performance Security and Bank is unable to make payment against the said Fixed Deposit receipts, the loss caused thereby shall fall on the contractor and the contractor shall forthwith on demand furnish additional security to the Employer to make good the deficit.

iii) The contractor will be allowed to start the work unless the Performance Security/Guarantee is submitted by him. In case of failure by the contractor to furnish the Performance Security/ Guarantee within specified period, Employer shall without prejudice to any other right or remedy available in law, be at liability to forfeit the Earnest Money absolutely.

iv) The Performance security shall be initially valid upto 60 days after recording of satisfactorily completion of work by the Employer. In case the time of completion of work gets and enlarge, the contractor shall get the validity of Performance Security extended to cover such enlarge time for completion of work on 60 days of recording of satisfactory completion of work by the Employer, the Performance Security shall be returned to the Contractor, without any interest.

v) The Employer shall not make a claim under the Performance Guarantee except for amounts to which the Employer is entitled under the contract (notwithstanding and/or without prejudice to any other provisions in the contract agreement) in the event of:

- a) Failure by the contractor to extend the validity of the Performance Guarantee as described herein above, in which event the Employer may claim the full amount of the Performance Guarantee.
- b) Failure by the contractor to pay the Employer any amount due, either as agreed by the contractor or determined under any of the clause/ conditions of the agreement, within 30 days of the service of notice to this effect by the Employer.
- c) In the event of the contract being determined or rescinded under provisions of any of the clause/ condition of the agreement, the Performance Guarantee shall stand forfeited in full and shall be absolutely at the disposal of the Employer.

28. COMPLETION CERTIFICATE

Within ten days of the completion of the work, the contractor shall give notice of such completion to the Employer and within days of the Engineer shall inspect the work. If there is no defect in the work the Employer shall furnish the contractor with a certificate of completion otherwise a certificate of completion indicating defects shall be issued but the work shall not be considered to be completed until the contractor shall have removed from the premises on which the work shall be executed all the scaffolding, surplus material, rubbish, and all huts and sanitary arrangements required for his work, people on the site in connection with the execution of the works as shall have been erected or constructed by the contractor and cleaned of the dirt, splashes, droppings of finishing items from all wood work, doors, windows, walls, floors or other parts of any building, in, upon or about which the work is to be executed or of which he may have had possession for the purpose of the execution thereof. If the contractor shall fail to comply with requirements of this clause on or before the date fixed for the completion of the work, the Employer may at the risk and cost of the contractor take action as he may think fit and the contractor take action as he may think fit and the contractor shall have no claim except for any sum actually realized by the sale thereof.

29. ESCALATION

Signature of Tenderer with the seal of the firm

a) If the price of materials (not being materials supplied or services rendered at fix prices by the Department and / or wages of labour required for execution of the work increase, the contractor shall be compensated for such increase the contractor shall be compensated for such increase as per provisions detailed below and the amount of the contractor shall accordingly by varied, subject to the condition that compensation for escalation in prices shall be available only for the work done during the stipulated period of the contract including such period for which the contract is validly extended under the provisions of Clause - 5 of Contract without any action under Clause – 2 and also subject to the conditions that no such compensation shall be payable for a work for which the stipulated period of completion is eighteen months or less. Such compensation for escalation in the prices of materials and labour when due, shall be worked out based on the following provisions.

- (i) The base date for working out such escalation shall be the last date of receipt of tender including extension, if any. .
- (ii) The cost of work on which escalation will be payable shall be reckoned as 85% the cost of the work as per the bills, running or final, and from this amount the value of material supplied by the Employer and proposed to be recovered in the particular bill shall be deducted before the amount of compensation for escalation is worked out. In case of materials brought to site for which secured advance is included in the bill full value of such materials as assessed by the Engineer in charge (and not the reduced amount for which secured advance has been paid), shall be included in the cost of work done for operation of this clause. Similarly, when such materials are incorporated in the work, the secured advance is deducted from the bill the full assessed value of the materials originally considered for operation of this clause shall be deducted from the cost of work shown in the bill running or final. Further the cost of work shall not include any work for which payment is made for any item at prevailing market rates. The cost work on which the escalation will be payable shall reckoned as below:
- a. Gross value of work done upto this quarter
 - b. Gross value of work done upto the last quarter
 - c. Gross value of work done since previous quarter (a-b)
 - d. Full assessed value of Secured Advance fresh paid in this quarter
 - e. Full assessed value of Secured Advance recovered in this quarter
 - f. Full assessed value of Secured Advance for which escalation is payable in this quarter (d-e)
 - g. Advance payment made during this quarter
 - h. Advance payment recovered during this quarter
 - i. Advance payment for which escalation is payable in this quarter (g-h)
 - j. Extra item paid as per clause 12 & 12 (A) based on prevailing market rate during this quarter:

Then,

$$X=C+F+I-J$$

$$Y+0.85 X$$

- k. Less cost of material supplied by the Department as per clause – 10 and recovered during the quarter:
 - l. Less cost of services rendered at fixed charges as per clause-34 and recovered during the quarter:
- Cost of work for which escalation is applicable:

$$W=Y-(K+L)$$

- (iii) The compensation for escalation for materials & labour shall be worked out as per the formula given below:

$$VM= W^A / 100 X^{(MI-MIo)} / MIO$$

VM- Variation in material cost i.e. increase or decrease in the amount in rupees to be paid or recovered.

W-Cost of work done worked out as indicated in sub Para (ii) above.

A-Component of materials expressed as per cent of the total value of work and is predetermined as 75.

MI- Index numbers of Wholesale prices in India for all commodities published by the Reserve Bank of India for the period under reckoning.

Mio- Index numbers of Wholesale prices in India for all commodities published by the Reserve Bank of India on the date of receipt of tenders.

$$VL= W X B/100 X \frac{(LI - LIo)}{LIo}$$

Signature of Tenderer with the seal of the firm

VL- Variation in labour cost i.e. increase or decrease in the amount in rupees to be paid or recovered.

W- Value of work done, worked out as indicated in sub para (ii) above.

B- Component of labour expressed as per cent of the total value of work and is predetermined as 25.

LI- Minimum wages for industrial workers published by the Reserve Bank of India for the period under reckoning as for the period under consideration.

LIo- Minimum wages for industrial workers published by the Reserve Bank of India and valid on the stipulated date of receipt of tenders.

b) The following principle shall be followed while working out indices mentioned in sub Para (iii) above.

(i) The compensation for escalation shall be worked out at half yearly intervals and shall be with respect to the cost of work done during the six calendar months of the said work. The first such payment shall be made at the end of the eighteen months after the month (excluding) in which the tender was accepted and thereafter at six monthly interval. At the time of completion of work, the last period for payment might become less than six months, depending on the actual date of completion.

(ii) The index (MI or LI) relevant to any six months for which such compensation is paid shall be the arithmetical average of the indices relevant to the six calendar months. If the period up to date of completion after the eighteen months covered by the last such installment of payment is less than six months, the index MI or LI shall be the average of the indices for the months falling within that period.

(iii) The base index (Mio or LIo) shall be the one relating to the month in which the tender was stipulated to be received.

c) In the event the price of materials and / or wages of labour required for execution of the work decreases there shall be downward adjustment of the cost of work so that the price of materials and / or wages of labour shall be deductible from the cost of work under this contract and in this regard formula herein before stated under this clause shall mutates mutandis apply, provided that no such adjustment for the decrease in the prices of materials and / or wages of labour aforementioned would be made in case of contracts in which the stipulated period of completion of the work is eighteen months or less.

d) Employer shall have the discretion to permit the IEEMA (India Electrical & Electronics Manufacturers' Association) clause for escalation in case of specialized works e.g. lifts and electrical and mechanical installations etc. where the price variation is not similar to building works.

30. ARBITRATION

a) Except where otherwise provided in the contract, all questions and disputes relating to the interpretation of the specifications, design ns, drawings and instructions herein before mentioned, and as to the quality or workmanship or materials used on the work or as to any other question, claim, right, matter or thing whatsoever in any way arising out of or relating to the contract, designs, specifications, estimates, instructions, orders on these conditions or otherwise concerning the works, or the execution or failure to execute the same, whether arising during the progress of the work or after the completion or abandonment thereof, shall be referred to the sole arbitration of the person appointed by the Director – General, Council of Scientific & Industrial Research. The arbitrator shall be appointed within 30 any party. The arbitrator to whom the matter is originally referred, being unwilling or unable to act for any reason, the Director – General shall appoint another person to act as arbitrator in accordance with the terms of the contract. Such person shall be entitled to proceed with the reference from the stage at which it was left by his predecessor. The arbitrator shall give a speaking award. The award of the Arbitrator shall be final and binding on the parties. The cost of the Arbitrator shall be borne equally by both the parties.

b) It is also a term of the contract that the party invoking arbitration shall specify the dispute or disputes to be referred to arbitration under this clause together with the amount or amounts claimed in respect of each such dispute.

Signature of Tenderer with the seal of the firm

c) It is also a term of the contract that if the contractor does not make any demand for arbitration in respect of any claim in writing within 90 days of receiving the intimation from the Employer that the final bill is ready for payment, the claim of the contractor will be deemed to have been waived and absolutely barred and the Employer shall be discharged and released of all liabilities under the contract in respect of these claims.

d) The Arbitrator may from time to time with consent of parties enlarge the time for making publishing the award.

e) Subject as aforesaid the provisions of the Arbitration and Conciliation Act, 1996, or any statutory modification or re-enactment thereof and the rules made there under and for the time being in force shall apply to the arbitration reference under this clause.

30. DISMANTLED MATERIAL

The contractor shall treat all material obtained during dismantling of a structure, services sub systems / installations, excavation of the site for a work etc., as employer's property and such material shall be disposed of to the best advantage of the Employer according to the instructions issued in writing by the Engineer.

31. PERFORMANCE GUARANTEE

Performance Guarantee may be taken from the Contractor before the award of work, by the officer authorized to award the contract, if and where considered necessary, to ensure that a part or whole of the contract is completed by the contractor. In case of non-performance, this guarantee could be encased.

*****SPECIAL CONDITIONS*****

1) These special conditions are meant to amplify the general specifications and general conditions of contract.

2) Work shall be done as per CPWD specification with latest correction slips

3) In case of any discrepancy, the order of precedence in interpretation shall be as under:-

- (i) Schedule of quantities
- (ii) Drawings
- (iii) Special conditions
- (iv) General conditions of contract
- (v) Special Specifications (if any)
- (vi) CPWD latest Civil and Electrical specifications
- (vii) IS codes
- (viii) BS and International codes
- (ix) Best Engineering practice

4.) The structural and architectural drawings shall at all time be properly correlated before executing any work. However, in case of any discrepancy in the item given in the schedule of quantities appended with the tender and drawings related to the relevant item the former shall prevail unless and otherwise given in writing by the Engineer.

No payment shall be made to the contractor for any damage caused by rain, snowfall, floods or any other natural cause whatsoever during the execution of work. The damage to work will be made good by the contractor at his own cost, and no claim on this account shall be entertained.

All materials used shall be as per the specifications and ISI mark wherever applicable. ISI marking referred relate to latest BIS Code as published Bureau of Indian Standard upto 30 days before the date of opening of tender.

The contractor shall give a performance test of the entire installations as per standard specifications and/or as directed by the Engineer and will also submit test certificate as are required by Municipal/ Electrical authority or any other authority. Nothing extra shall be payable for the same other than fees paid to such authorities, which shall be reimbursed on production of receipts.

5) CEMENT

Signature of Tenderer with the seal of the firm

- ii) The contractor shall procure 33 grade (conforming to IS:269) or 43 grade (conforming to IS:8112) ordinary port land cement, as required in the work, from reputed manufacturers of cement, having a production-capacity of one million tons per annum or more, such as ACC, L & T, J.P. Rewa, Vikram, Shri Cement, Birla Jute and Cement Corporation of India etc., and holding license to use ISI certification mark for their product whose name shall be got approved from Engineer-in-charge. Supply of cement shall be taken in 50 Kg. bags bearing manufacturer's name and ISI marking, samples of cement arranged by the contractor shall be taken by the Engineer-in-charge and got tested in accordance with provisions of relevant BIS codes. In case test results indicate that the cement arranged by contractor does not conform to the relevant BIS codes, the same shall stand rejected and shall be removed from the site by the contractor at his own cost within a week's time of written order from the Engineer-in-charge to do so.
- iii) The cement shall be brought at site in bulk supply of approximately 50 tones or as decided by the Engineer-in-charge.
- iv) The cement godown of the capacity to store a minimum of 2000 bags of cement shall be constructed by the contractor at site of work for which no extra payment shall be made. Double lock provisions shall be made to the door of the cement godown. The keys of one lock shall remain with the Engineer-in-charge or his authorized representative and the key of the other lock shall remain with the contractor. The contractor shall be responsible for the watch and ward and safety of the cement godown. The contractor shall facilitate the inspection of the cement godown by the Engineer-in-charge at any time.
- v) The contractor shall supply free of charge the cement required for testing. The cost of tests shall be borne by the Department if the results are as per specifications. If the test results found the properties of cement not as per specification then the contractor will bear the cost of testing.
- vi) After completion of the work or on determination / termination of the contract, the theoretical quantity of cement to be used in work shall be calculated on the basis of statement showing quantity of cement to be used in different items of work provided in current Schedule for the purpose printed by CPWD. In case any item is executed for which the standard constants for the consumption of cement are not available in the above mentioned statement or cannot be derived from this statement, the same shall be calculated on the basis of standard formula to be laid down by the Engineer. Over this theoretical quantity of cement, shall be allowed a variation up to 3% plus/minus for works estimated cost of which as put to tender is not more than Rs.10. Lakh and upto 2% plus/minus for works estimated cost of which as put to tender is more than Rs. 10 Lakh. The difference in the quantity actually issued to the contractor and the theoretical quantity including authorized variation, if not returned by the contractor, shall be recovered at twice the issue rate, without prejudice to the provision of other conditions regarding return of materials governing the contract. In the event of its being discovered that the quantity of cement which is less than the quantity ascertained as herein before provided (allowing variation on minus side as stipulated above) the cost of quantity of cement not so used, shall be recovered from the contractor on the basis of stipulated issue rates and cartage to site.
- vii) Cement brought to site and cement remaining unused after completion of work shall not be removed from site without written permission of the Engineer-in-charge.

6.) STEEL

- i) The contractor shall procure steel reinforcement bars conforming to relevant BIS codes from reputed manufacturers as approved by the Engineer-in-charge. The contractor shall have to obtain and furnish test certificates to the Engineer-in-charge in respect of all supplies of steel brought by him to the site of work. Samples shall also be taken and got tested by the Engineer-in-charge as per the provisions in this regard in relevant BIS codes. In case the test results indicate that the steel arranged by the contractor does not conform to BIS codes, the same shall stand rejected and shall be removed from the site of work by the contractor at his own cost within a week's time from written orders from the Engineer-in-charge to do so.
- ii) The steel reinforcement shall be brought to the site in bulk supply of 10 tonnes or more as decided by the Engineer-in-charge.
- iii) The steel reinforcement shall be stored by the contractor at site of work in such a way as to prevent distortion and corrosion and nothing extra shall be paid on this account. Bars of different sizes and lengths shall be stored separately to facilitate easy counting and checking.
- iv) For checking nominal mass, tensile strength, bend test, re-bend test etc., specimen of sufficient length shall be cut from each size of the bar at random at frequency not less than that specified below:

Signature of Tenderer with the seal of the firm

<i>Size of bar</i>	<i>For consignment below 100 tones</i>	<i>For consignment over 100 tones</i>
<i>Under 10 mm dia.</i>	<i>One sample for each 25 tones or part thereof.</i>	<i>One sample for each 40 tones or part thereof.</i>
<i>10 mm to 16 mm dia.</i>	<i>One sample for each 35 tones or part thereof</i>	<i>One sample for each 45 tones or part thereof.</i>
<i>Over 16 mm dia.</i>	<i>One sample for each 45 tones or part thereof</i>	<i>One sample for each 50 tones or part thereof.</i>

- v) The contractor shall supply free of charge the steel required for testing. The cost of tests shall be borne by the department if the results are as per specifications. If the test results found the properties of steel not as per specifications then the contractor will bear the cost of testing.
- vi) The provision of Para 4(v) of Special Conditions shall apply Mutatis-Mutandis in the case of steel reinforcement or structural steel sections (each diameter/section or category shall be considered separately) except that the theoretical quantity of the steel shall be taken as the quantity required as per design or as authorized by the Engineer, including lappages, plus 3% wastage due to cutting into pieces. Over this theoretical quantity 2% plus/minus shall be allowed as variation due to wastage.
- vii) Steel brought to site and steel remaining unused shall not be removed from site without the written permission of the Engineer-in-charge.

7) ELECTRICAL WORK

The provision of para 5(v) of Special Conditions shall apply Mutatis–Mutandis in the case of cables (other than under – ground cables), wires, conduits / GI pipes, GI/MS sheets used in various items of work shall be calculated on the basis of measurements recorded in the measurement books for the purpose of payment and for assessing the consumption of materials used in the works. Over this quantity a variation of 5% plus shall be allowed for wastage of materials during execution in case of cables (other than under – ground cables), wires, conduits/GI pipes, and 10% plus in case of GI/MS sheets.

8.) Unless otherwise provided in the schedule of quantities the rates tendered by the contractor shall apply for all heights, lifts, leads and depths of the work and nothing extra shall be payable on this account.

9.) The surplus excavated earth which is beyond the requirement of the Employer’s work may be allowed by the Employer to be disposed off by the contractor on his own or sell the surplus excavated earth to private parties at his discretion but nothing extra will be paid for the carriage or disposal of surplus earth if the same is not required on any other work of the Employer.

10.) CPWD mode of measurement shall be followed. 11.) Engineering staff/ technical staff required to be provided by Contractor for Superintendence of work

Staff to be employed by contractor on works: The contractor shall employ the following technical staff during execution of works :-

- (a) For building and road works
- (i) One Graduate Engineer, when the tendered cost of work exceeds Rs 10 lakhs.
- (ii) One qualified Diploma holder (overseer) with experience not less than 3 years when the tendered cost of work exceeds Rs. 5 lakhs but is less than Rs 10 lakhs.
- (iii) One qualified Diploma holder when the tendered cost of work is more than Rs 2 lakhs but less than Rs 5 lakhs.
- (b) For sanitary and water supply works One qualified diploma holder with experience of not less than 5 year,

Signature of Tenderer with the seal of the firm

out of which one year should be in sanitary and water supply works when the tendered cost of work is more than Rs 50,000.

(c) For electrical works

(i) One qualified Graduate Engineer possessing Degree in Electrical Engineering from recognized university with an experience of not less than 3 years or a Diploma holder in Electrical Engineering with an experience of not less than 7 years when the tendered cost of the work is not less than Rs 1.5 lakhs.

(ii) One Graduate Electrical Engineer with two years experience or a Diploma holder in Electrical Engineering with experience of not less than 3 years, when the tendered cost of the work is more than Rs 75,000 but less than Rs 1.5 lakhs.

(iii) One Diploma holder in Electrical Engineering with experience of not less than 3 years when tendered cost of work is more than Rs 37,000, but less than Rs. 75,000.

(iv) One licensed Supervisor with experience of not less than 3 years when the tendered cost of work is more than Rs 7,500 and less than Rs 37,000.

(d) In case the contractor fails to employ the technical staff as aforesaid, he shall be liable to pay reasonable amount not exceeding the amount shown below for each month of default.

(i) In case when a Graduate Engineer is to be employed.

....Rs. 15,000/-

(ii) In case when a qualified Diploma holder is required to be employed.

...Rs. 10,000/-

(iii) In case when a technical Supervisor is required to be employed.

...Rs 7000/-

(e) The department also reserves the right to appoint an Engineer for supervising the work at the site & cost of the contractor.

Signature of Tenderer with the seal of the firm